



Bharat Heavy Electricals Limited
Industry Sector, Transmission Business Group
Materials Management
Integrated Office Complex
Lodhi Road, New Delhi-110 003
Telephone : 011-41793456
E-mail : dghosh@bhelindustry.com

SUBJECT- Corrigendum-2 TO NIT No.13210

DATE 28.12.2012

- | | | | |
|----|--------------------|---|---|
| 1. | Project | : | PGCIL, N.E. AGRA HVDC |
| 2. | Equipment / Item | : | Ventilation System
(Package-C) |
| 3. | Enquiry No. / Date | : | 342E314 Dtd. 26.11.2012, Due on : 11-Jan-13 |

With reference to the above NIT, "Annexure (PBD)-B4 Page 1 / 2" as mentioned in PQR for Air-conditioning & Ventilation System enclosed.

All other terms and conditions of tender shall remain same. Kindly ensure to submit your offer by due date.

(Dibyendu Ghosh)
Sr. Manager (TBMM)

1

Inspection Level & MQP Requirement(For On -shore Supply)

144

Sl. No.	Description	Requirement of MQP	Inspection Level
✓	Circuit Breakers	Yes	IV
	Isolators/earth switch	Yes	IV
	Current Transformers	Yes	IV
	Tuning CTs	No	II
	Capacitive voltage Transformers	Yes	IV
	Filter Capacitors	Yes	IV
	Surge Arrestors	Yes	III
	PLCC equipments Viz. PLCC Terminal, Protection Coupler, Coupling Device, Wave Trap but excluding EPAX / HF Cable	Yes	III
	Control & Relay Panels and Sub-Station automation system	Yes	III
	Power Cables	Yes	III
	Control Cables	Yes	III
	All Transformers	Yes	IV
	Oil filled reactor	Yes	IV
	Transformer/reactor oil	--	III
	Fire Protection System		
	a) Pumps, Motors, Engines, r compressors and their spares	No	III
	b) Panels, Hydro pneumatic tank, strainers, Extinguishers, Conventional Fire Alarm Panels and Pipes	No	II
	c) Others	No	I
	Ac and Ventilation System 0. (Split Units)	No	II
	a) Control Panels GI Sheets for ducting	No	III
	b) Chilling unit, AHU, Fans, pumps, motors, MS & GI pipes	No	II
	c) others	No	I
	LV/MV Switchgear (AC and DC DBs)	Yes	III
✓	Steel Structure (Lattice / Pipe)	Yes	III
	Earthwire	Yes	III
✓	Bus Post Insulators	Yes	III
	Disc Insulator	Yes	IV
	AAC/ ACSR Conductor	Yes	IV
	Clamps & Connectors / Spacers	Yes	III
	Bay Marshalling box/ Lighting Panels/ lighting Switch Boards	No	II
	String Hardware	Yes	IV
	Cable lugs & Glands	No	I



Pre-award discussion/

10/13

± 800 KV, 6000 MW HVDC MULTI TERMINAL SYSTEM PACKAGE ASSOCIATED WITH NER/ER— NR/WR INTERCONNECTOR-I PROJECT (SPECIFICATION NO. C-61901R-S056-8).

Handwritten signatures and stamps are present at the bottom of the page, including a circular stamp of BHEL Transmission Business Group, Industry Sector, New Delhi-3.