



Bharat Heavy Electricals Limited
Industry Sector, Transmission Business Group
Integrated Office Complex
Lodhi Road, New Delhi-110 003
Phones: 011-41793467/110, Fax: 011-24369509

SUBJECT- Corrigendum-4 TO NIT No.13925

DATE 16.05.2013

- | | | | |
|----|--------------------|---|---|
| 1. | Project | : | HCC Kishanganga |
| 2. | Equipment / Item | : | 220/33 kV Circuit Breakers |
| 3. | Enquiry No. / Date | : | 142E422 Dtd. 11.03.2013, Due on: 24.05.13 |

This is with reference to the above mentioned project and the item, kindly note the following;

- a) Type Test report validity – As per specification. [Clause no. 1.5 of section-1]
- b) Control cubicle Protection – IP-55 is acceptable. [Clause no. 3.9.4 (a) of section-3]
- c) Rupture disc - It is not applicable. [Clause no. 1.3 (Item no. 6) of Section-1]
- d) Higher voltage rating of Circuit breaker is also acceptable to meet the requirements of the technical parameters. [Clause no. 1.3 (Item no. 1 & 2) of section-1]
- e) The offered CBs shall also be type tested for Low temperature test as per clause no. 6.101.3 of IEC 62271-100 due to the site temperature of -12o C. [Clause no. 1.4 (b) of Section-1]

The above clarifications/information is applicable for both types of Circuit Breakers i.e. 220 kV & 33 kV.

All other terms and conditions of tender shall remain same. Kindly ensure to submit your offer by due date i.e. 24.05.2013.

Manager (TBMM)