



**OPEN TENDER ENQUIRY FOR ELEVATORS FOR 1X 800 MW GSECL WANAKBORI
STPP, UNIT No. 8**

Ref No. : PE/PG/WAN/E-5127/2015

Date: 08.03.2016

CORRIGENDUM/ ADDENDUM- 8

Tender Enquiry no.: PE/PG/WAN/E-5127/2015
Date: 18.10.2015

EXTENDED DUE DATE
21 Mar 2016
10:00 AM

Ma'am/ Sir,

Please find below BHEL clarification on Pre-Bid query asked by bidder for subject enquiry.

Sl. No.	Pre-Bid query	BHEL clarification
1	<p>As per IS14665, the car size required is 1700 x 2500 and the entrance is 1700 x 2100 for 2000kgs capacity lift. To provide the required entrance, we required minimum shaft width of 2900mm for 4 panel centre opening door.</p> <p>Or we shall provide automatic uplifting door with 1700 x 2100 entrance in the shaft size of 2600 x 2800 but the minimum floor height has to be 3800mm.</p> <p>or shall we consider 1100 x 2100mm entrance?</p>	<p>Bidder to note that car entrance shall be 1700 mm only for 2000 Kg cap elevator. Car & landing door shall be automatic horizontal sliding door type with type of door suitable for shaft size of 3000 (entrance side) X 3000 mm for TG building.</p>

The bidders who have already submitted their bids for the said tender enquiry, may go through the corrigendum and in case it is felt required, may furnish revised bid with envelopes duly superscribed as "Revised bid (only to be considered)".

All bidders are requested to regularly visit BHEL websites www.bhel.com (Tender Notifications Section) OR www.bhelpem.com (http://www.bhelpem.com/Tenders_Rev/NewTenders.aspx). All future corrigendum(s), addendum(s), amendment(s), if any, for this tender shall be hosted only on above websites.

Thanking you,

Yours faithfully,
For and on behalf of BHEL


08/03/2016

AMIT KUMAR
(ENGINEER/Project Group-1-1)

Please reply to:

Amit Kumar-Engr./ Shri Prakash-Sr. Engr.
PEM/PGI-1

Power Project Engineering Institute Building
HRD & ESI Complex, Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-436 8831, 421 3621