

CORRIGENDUM- 2 TO TENDER NOTICE BHEL PSSR SCT 1546, Dated:27/3/2014

Rate Contract for Design, Manufacturing, supply, receipt at site, construction and Finishing works if any etc and Handling over to site removable/re erectable type pre- engineered, prefabricated steel storage closed shed for forthcoming power projects in India for 2 years.

Sl.No.	Existing Clause	To Be read as	Remarks
I	VOLUME-IA PART – I CHAPTER - V T&Ps provided by BHEL 1.5.1 BHEL will not provide any T & Ps for the this scope of work 1.5.2 All the tools and plants required for execution of the above work are in contractor’s scope.	VOLUME-IA PART – I CHAPTER - V T&Ps/Others provided by BHEL 1.5.1 BHEL will not provide any T & Ps for the this scope of work 1.5.2 All the tools and plants required for execution of the above work are in contractor’s scope. 1.5.3 Leveled ground will be provided for construction of sheds by BHEL.	Clause 1.5.3 Added

II	The clarifications issued by BHEL for the queries raised by a bidder are mentioned below:		
	Query raised by Bidder	Clarification issued by BHEL	
	Leveled Surface to be provided by BHEL.	Please refer to clause 1.5.3 in Chapter V Volume IA PART – I (as above)	
	Finished floor level (FFL) of store shed considered is 600 mm from Natural ground level(NGL). If the 600 mm increases due to road level, etc additional material or labour to be charged extra.	Already covered under Clause 3 of Technical Specifications	
	Civil has been designed for a soil bearing capacity of 15 T/m2 .If the soil condition is bad (clay etc.) with lesser SBC, additional material or labour to be charged extra.	Already covered under Clause 3 of Technical Specifications, Clauses reproduced below; In case the depth of foundation is increased or decreased, the new quantities will be reworked and the shed amount revised. Similarly any change in the size of the shed /other conditions, the new quantities shall be re worked and the amount revised.	
	Manual gear operated rolling shutter can be provided instead of sliding door but the price of rolling shutter will be higher than sliding door.	Sliding door only to be provided	
	Additional lighting is requested outside the store shed around the building in some sites, this lighting can be done at extra cost.	No lighting outside the store shed is envisaged in this Tender.	
	Drawing of semi closed shed available in the tender but scope is different.	Drawings of Semi Closed Storage Sheds to be ignored. Please refer to revised Elevation Drawing of Closed Shed attached below.	
	Request for a grace period of 10 Days for completion of the work.	Tender Condition Prevails	

* All Other Conditions remain Unchanged. Bidders are requested to submit the Corrigendum duly signed, since this forms part of the tender.

		GM/HR&CONTRACTS	

