

Ref.: BHE/PW/PUR/VNSR-CRH-Tower/1648/Corrigendum-01

DT: 15/07/2016

To,

ALL BIDDERS

Sub: Corrigendum 01 for Clarification of technical query & for Extension of Due date of offer submission.

Job: PROVIDING SERVICES OF 02 NOS OF TOWER CRANE (06 MT) WITH CHASSIS ON MONTHLY HIRING BASIS FOR RENOVATION & RETROFITTING OF EXISTING ELECTROSTATIC PRECIPITATORS & DUCTS WORK AT NTPC, VINDHYACHAL SUPER THERMAL POWER STATION.

Ref:-

1) Tender Specification Number: **BHE/PW/PUR/VNSR-CRH-Tower/1648**

Bidders to kindly take note of the following:

=====
AA) Clarifications to Bidder's queries and amendments

1. **Clause no 1.1.10: "Electrical Power requirement to operate the crane" of Technical Conditions of Contract (TCC) - Volume IA:** Bidder shall clearly indicate electrical power single point of source to Tower crane shall be arranged by Bidder.

Query: - Electrical power and all works relating to the same any installation deadline as mentioned in the tender.

BHEL Reply: Bidder shall clearly indicate electrical power requirement to operate the crane which shall be provided by BHEL on free of charge basis. Single point will be provided by BHEL at the bottom of the Tower crane (Isolator Box or distribution box of Tower crane).

BB) Extension of due date for offer submission

The due date of offer submission has been extended up to **18/07/2016, 15.00 hrs.**

Note: The queries not addressed herein are deemed construed that the terms & conditions of the tender shall remain unchanged.

=====
All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Ref.: BHE/PW/PUR/VNSR-CRH-Tower/1648/Corrigendum-01

DT: 15/07/2016

Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL <https://bheleps.buyjunction.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,
Yours faithfully,

Sr. Engineer (Purchase)