

Bharat Heavy Electricals Limited
 (High Pressure Boiler Plant) Tiruchirappalli – 620014,
 TAMIL NADU, INDIA An ISO 9001
 CAPITAL PURCHASE /MATERIALS MANAGEMENT / MFG

ENQUIRY – Corrigendum 1	Phone: +91 431 257 7645 Fax : +91 431 252 07 19 Email : pgavictor@bheltry.co.in Web : www.bhel.com / www.tenders.gov.in
--------------------------------	---

NIT_14239	Enquiry Number: 2681300022	Enquiry Date: 16.05.13	Revised due date for ubmission of quotation : 29.06.13
------------------	--------------------------------------	----------------------------------	---

You are requested to quote the Enquiry number date and due date in all your correspondences. This is only a request for quotation and not an order

ITEM DESCRIPTION: Supply and Installation of Eco friendly Maintenance Free Earthing
Details of Corrigendum

- The above mentioned tender due date has been extended to 29.06.13 and tender will be opened at 14:30 Hrs on the same date.
- Annexure I, Part B, Sl.No. 4.2 revised as below (red ink).

Annexure I, Part B, Sl.No.	Description for BHEL requirement
----------------------------	---

4.2	<p>Highly conductive and Eco friendly backfill material :</p> <p>The backfill material shall be highly conductive and should be certified as non-polluting and non-hazardous by one of the Accredited / Recognized National /International Laboratories.</p> <p>The backfill Material shall be carbon based and of low resistance, non-corrosive, highly conductive carbon based powdered material that improves grounding effectiveness, especially in areas of high soil resistivity such as rocky and sandy areas. This material shall be suitable to be installed in either slurry or dry form. The backfill material shall confirm to the following specifications:</p> <ol style="list-style-type: none"> Shall be highly electrically conductive and non-soluble. Shall not leach into ground. Shall have a resistivity of less than 0.1 ohm meter as per clause 14.5 (d) of IEEE 80 Shall be compatible with all copper grounding systems Shall contain a corrosion inhibitor to mitigate corrosion of copper Shall not contain hazardous chemicals and bentonite Deleted Shall not be affected by drought and shall be stable between -10° to +50° C temperature. Shall not depend on continuous presence of moisture for conductivity. Shall be suitable for any kind of soil suitable quantity of this backfill compound shall be used per earth pit. <p>Note: sample of Backfill material shall be sent along with the offer. (100g)</p>
-----	---

All other terms and conditions as published in the NIT_14239 remain unaltered

Confirmation of acceptance for BHEL commercial terms & conditions and Price Bid formats have been posted in BHEL Corporate web site www.bhel.com or from the Government tender website <http://tenders.gov.in> (public sector units > Bharat Heavy Electricals Limited page) under Nit No. reference :14239

Tenders should reach us before 14:00 hours on the due date Tenders will be opened at 14:30 hours on the due date Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present	Yours faithfully, For BHARAT HEAVY ELECTRICALS LIMITED MGR/CP & SP
--	---