

HR-TAX (WATER WORKS)  
BHEL HARDIWAR

Ref: HR-TAX/WW/NIT


Dated : 08/12/2017


**Subject: Corrigendum in Technical Specification in Indent No. 20172630 dated 05/09/2017 (Vertical Induction Motor 75 HP) for SPH-3.**


The following points are to be added as corrigendum in technical specification of above mentioned Indent:

- 1-The material of impeller should be of stainless steel/ Bronze, casing should be of cast iron and connecting shaft should be of stainless steel.**
- 2- Motor-Pump starting should be of 3-Phase Star-Delta type.**

There is no change in any other technical specification of Vertical Induction Motor.

  
(Jitendra Singh)  
Sr. Engineer (Water Works)

  
Sr.Engineer (Water Works)

  
Sr. Manager (Water Works)

  
DGM (HR-TEX & WW)

AGM(PPX-CEN/CAP)