

Ref: BHE/PW/PUR/UKT BLROH U#5/1375/Corrigendum-01

Date: 30/12/2014

Sub: Corrigendum 01- Issue of Clarifications

.....Page 1 of 1.....
To

ALL BIDDERS

Job: Work for Dismantling of existing Re-Heater rear assembly (89 nos. of HRH coils) and Erection & Commissioning of new Reheater Rear assembly of boiler #5 of 210 MW units at Ukai Thermal Power Station.

T.S.No: BHE/PW/PUR/UKT BLROH U#5/1375

Bidders to kindly take note of the following:

=====

AA) Clarification to Bidder's Query:

<u>Sl No.</u>	<u>Bidder's Query</u>	<u>Clarification</u>
1	<u>Kindly confirm/provide the following details.</u> 1) Weight of each HRH coil & No of joints in each coil alongwith size of Coil. 2) Clarify Scope of Refractory work.	1) Total no. of coils are 89 nos. As per no. of coils total 712 no. joints shall come but it may increase as per vender lifting arrangement (water wall cutting and spacer tube cutting and its installation) for New HRH coils. One No. Coil weight is approx. 590 kg. Size: - 10.6 mtr. and OD & Thickness (54/3.6, 47.63/3.4&4, 54/4.5) 2) Rear arch water wall slope area and dog house refractory work is to be carried out by bidder under E&C of HRH coils and refractory material shall be provide by customer.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-1" against NIT No.20832 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)