

EXPRESSION OF INTEREST

BHEL is setting up a 4 x 125 MW Thermal Power Plant in Kosti, Sudan. After construction, settlement has been noticed in the ground floor/ Cable Trenches/ Minor foundations etc., rested on compacted filled up soil in the following areas:

Area	Observed settlement (approx.)
River Water Intake Pump House – MCC Room	300 – 800 mm
CW Pump House – MCC Room	50 -- 200 mm
Switch Yard	50 -- 100 mm

Rectification/ restoration of settled structures including stabilization of filled up soil underneath are required to be carried out for the above areas so as to ensure that no further sinking / settlement takes place. BHEL is looking forward for suitable parties who can carry out the above mentioned works. The work has to be carried out during running Power Station without dismantling/breaking of existing structures including equipment.

Eligible and interested parties who are confident to carry out the above works having experience of similar work may submit their EOI in a sealed cover super scribed “Expression of Interest for carrying out Rectification/ restoration of settled structures at 4 x 125 MW TPP, Kosti-Sudan”. The EOI should include **“Proposed Methodology for carrying out work, credentials of the party and similar work experience details”**.

The documents attached with this EOI are as follows:

1. SYNOPSIS OF SUDAN PROJECT
2. GEO-TECHNICAL INVESTIGATION REPORT- 5 FILES.
3. PLOT PLAN- HIGHLIGHTED FOR SWITCHYARD & MCC-CWPH AREA
4. DRAWING OF MCC ROOM CW PUMP HOUSE
5. DRAWING OF MCC ROOM RIVER INTAKE PUMP HOUSE
6. DRAWING OF RIVER INTAKE PUMP HOUSE AREA
7. SITE PHOTOGRAPHS
8. DRAWING OF SWITCH_YARD_AREA



Engineering Services and Design

Since 1982

WHEN YOU NEED
ENGINEERING SOLUTIONS



REPORT ON

GEOTECHNICAL INVESTIGATION

FOR

ASSESSMENT ON SOIL SETTLEMENT OF COMPACTED
FILLS
AT 4X125 MW KOSTI THERMAL POWER STATION
RABAK, WHITE NILE STATE
SUDAN



SUBMITTED TO
BHARAT HEAVY ELECTRICALS LIMITED
(BHEL)

FEBRUARY 17, 2014



32 Years of Service Excellence



Khartoum : Tel: +249183248886
Fax: +249183248866
P.O.Box : 95 Khartoum North
esdengco@yahoo.com
www.esd-sudan.com.sd
esd.eng.co@gmail.com



Contents

1. Introduction	2
2. The Field Investigation	3
2.1 Drilling of Boreholes	3
2.2 Groundwater	3
3. Soil Conditions	3
4. Laboratory Testing	4
4.1 Objectives of the Testing Program	4
4.2 Classification Tests	4
4.2.1 Consistency of Clays	4
4.2.1.1 Plastic Limit (PL) & Liquid Limit (LL)	5
4.2.1.2 Shrinkage Limit	5
4.2.2 Grain Size Distribution	5
4.2.2.1 Sieve Analysis Test	5
4.2.2.2 Hydrometer Test	6
4.2.3 Natural Moisture Content	6
4.3 Specific Gravity	6
4.4 Bulk Density Test	7
4.5 Permeability Test	7
4.6 Free Swelling	7
4.7 Swelling Pressure Test	8
4.8 Consolidation Test	9
4.9 Collapse Potential Test	9
4.9.1 Single Oedometer Collapse Test	9
4.9.2 Double Oedometer Collapse Test	10
4.10 Pin Hole Test	11
4.11 Sensitivity Tests	12
4.12 Chemical Tests	13



5. Analysis of the Results	13
5.1 General Review	13
5.2 Origin of Collapsible Soils	14
5.3 Collapsible Soil Behavior	14
5.4 Identification of Collapsible Soil	15
5.5 Evaluation of Collapse Potential	16
5.6 Classification of Collapsible Soil	16
5.7 Use of Collapsible Soils as A Compaction Fill Material	17
5.8 The Actual Situation in Kosti Thermal Power Station, Rabak	17
5.9 Identification of Collapsible Soil	18
5.10 Evaluation	19
5.11 Collapse Classification	19
5.12 Data About the Fill Material	20
6. Discussion of the Results	20
6.1 Proposal of Remedial Measure	20
7. Conclusion	21
8. References	22
9. Appendix (A)	24
10. Appendix (B-1)	43
11. Appendix (B-2)	58
12. Appendix (C)	70
13. Appendix (C-1)	77
14. Appendix (C-2)	88
15. Appendix (D)	93
16. Appendix (E)	96
17. Appendix (F)	101
18. Appendix (G)	106

1.0 Introduction:

BHEL contracted with **Engineering Services & Design (ESD)**, geotechnical consulting office, to carry out soil investigation to assess soil settlement of compacted fills at 4x125MW Kosti Thermal Power Station, in Rabak town, White Nile State.

The site investigation consisted of drilling thirteen (13) boreholes. Six boreholes; BH.1, BH.2, BH.3, BH.4, BH.5 and BH.6 were drilled at power station area. Another six boreholes; BH.7, BH.8, BH.9, BH.10, BH.11 and BH.12 were drilled at river water intake pump house location. Last borehole; BH.13 was drilled at intake water pipeline route. Undisturbed and disturbed soil samples are taken as well as carried out appropriate field and laboratory testing. The field work was conducted during the period from 18th to the 26th of November 2013.

The following conditions were part of the agreement;

1. The client has determined the number of borehole to be drilled, their locations and depth, as well as frequencies of field tests. ESD followed the proposal with that specific program for testing and drilling.

2. Sampling in both disturbed and undisturbed tube had been difficult because some of layers at boreholes were very soft and almost saturated. At some of the depths, undisturbed tubes were recovered empty as shown in profile.

3. Two bulk soil samples marked SPILE & PCL collected from borrow areas were handed over by the client. Laboratory tests carried out for these samples are Atterberg limit, Sieve Analysis, Specific Gravity, Hydrometer, Compaction, Single and Double oedometre. Results of these tests are shown separately in Appendix (F).

This report presents the results of the field investigations, laboratory tests, analysis of the results and recommendations for the remedial measures.

2.0 The Field Investigation:

2.1 Drilling of Boreholes

Thirteen boreholes were drilled in the specified locations. The location of these boreholes are shown in Fig (1). The boreholes were drilled using a rotary soil mechanics drilling rig. Disturbed soil samples and undisturbed samples were collected at one-meter depth intervals for visual inspection, identification of the soil type and laboratory testing. The Standard Penetration Test (SPT) was performed at a depth interval of 1.5m at some boreholes (shown the soil profile). A split spoon sampler, 50mm out side diameter was driven by the blows of a standard hammer weighing 64-kg and falling freely from a height of 760mm. The number of blows required to drive the tube a penetration of 300mm was taken as the SPT N-value of the soil tested at a specified borehole depth. The SPT results are shown in Appendix (A) at the corresponding borehole depths in terms of the measured N values.

It's to be mentioned that the boreholes at river intake pump house and power station were all in the compacted fill area.

2.2 Groundwater

The level of the ground water table was not observed at most of boreholes. In borehole No.7 ground water was observed at 8.0m depth. The moisture content in most of borehole were high and soil almost saturated below 2.0m depth, this may be due to ingress of water from rainfall or other sources in stations.

3.0 Soil Conditions:

The soil profile for the boreholes is shown in Fig. (2) and Appendix (A). The soil profile at most of boreholes are relatively similar. In power station the boreholes BH.1, BH.2, BH.3, BH.4, BH.5 and BH.6 indicate dark brown to light grey clayey sand (SC) layer and silty clay of low plasticity (CL) layer, followed by high plasticity (CH) layer. This three layers may happen in different sequences. The Boreholes around the river water pump house BH.7, BH.8, BH.9, BH.10, BH.11 and BH.12 indicate dark brown and greyish brown,

clayey sand (SC) layer and low plasticity silty clay (CL) layer. The SPT results for these boreholes indicate loose and soft soil. Except borehole No.10 where the SPT were high. BH.13 near pipe line, profile indicate to reddish brown poorly graded of silty sand (SP-SM) layer, followed by light brown clayey sand (SC) layer.

4.0 Laboratory Testing:

4.1 Objectives of the Testing Program


Laboratory testing program was conducted to evaluate the physical and chemical properties of the soils encountered during the boring. The tests included bulk density and moisture content, atterberg limits, grain size distribution, specific gravity, chemical tests, free swell index, consolidation, sensitivity, collapse potential using single and double oedometer, pinhole and permeability. The procedures followed were in general conformance with those recommended in the British Standard BS 1377 (1990) and American Society for Testing and Materials ASTM.

4.2 Classification Tests

The objective of these tests is to reveal soil types encountered at different depths of the boreholes. Tests carried out included atterberg limits, shrinkage limit and grain size analysis. All these classification tests confirmed the soil profiles shown in Appendix (A). Unified Soil Classification System (USCS) was followed for soil classification. See Fig. A-1 and Fig. B-1.

4.2.1 Consistency of Clays

The physical properties of clays are considerably influenced by the amount of water percent. Atterberg limits are the limits of water content used to define soil behavior. The consistency of soils according to Atterberg limits gives the following diagram.



4.2.1.1 Plastic Limit (PL) and Liquid Limit(LL)

The program of tests were carried out on clayey soil samples taken from different depths, based on standard test procedures at ASTM D 4313-03.

At boreholes in power station area, the results gave liquid limit values ranging between 75% to 34% and plastic index in the range of 45% to 16%, this range of Atterberg limits indicate possibility of occurrence medium to high potential for swelling. At the boreholes in the river water intake pump house area, results gave liquid limit values ranging between 42% to 20% and plastic index range between 23% to 10%, the range indicate possibility of occurrence medium to low swelling potential. Liquid limit values in the pipe line borehole between 23% to None and plastic index in range 8% to None, this range indicate to low swelling potential for swelling for the clayey samples.

4.2.1.2 Shrinkage Limit

The shrinkage is a measure of the average oven dry length of the sample after shrinkage to the original length which occurs at an initial water content at or above the Liquid Limit. According to the standard (ASTM D 427-98), results for samples from the boreholes are shown in soil profile. Range of the results at power station area between 7.71% to 20.0%, at river water intake pump house area between 5.34% to 10.79% and at pipe line nearly 2.07%. All of this results indicate to low shrink properties.

4.2.2 Grain Size Distribution

Grain size distribution or the percentage of the various size of soil grains percent in a given dry soil sample is carried out by mechanical sieve analysis for coarse grain and whereas fine-grained soils are analysed by the hydrometer method.

4.2.2.1 Sieve Analysis Test

The grain size distribution curve of the soil samples was determined in the laboratory. The results of the tests are shown in Appendix (B-1). Test was carried out according to ASTM D 1140-03.

4.2.2.2 Hydrometer Test

Distribution of soil particles having sizes less than 75 micron (Fine Grained soils) is determined by a sedimentation process using a hydrometer to obtain the necessary data such as the borderline between clay and silt. In appendix (B-2), results are shown for the hydrometer curves to different some samples.

4.2.3 Natural Moisture Content

The natural moisture content was determined from undisturbed soil samples. The test was performed according to ASTM D 2216-98. The test results are shown in the soil profile at Appendix (A) and figures(2). As mentioned previously, inspection by visual description reference a high moisture content at upper layers between 2.0m and 6.0m depth was observed.

4.3 Specific Gravity

Test is performed to determine the specific gravity of soil by using a pycnometer. Specific gravity is the ratio of the mass of unit volume of soil at a stated temperature to the mass of the same volume of gas-free distilled water at a stated temperature. standard reference for this test is ASTM D 854-02. Table (4.1) shows the results of specific gravity at different location.

BH. No.	Depth (m)	Specific Gravity
1	3.0	2.78
2	2.0	2.82
4	2.0	2.74
7	8.0	2.72
7	6.0	2.69
8	8.0	2.86
9	10.0	2.85
12	8.0	2.78

Table No.(4.1) Specific Gravity Test Results

4.4 Bulk Density Test

Table (4.2) shows the results of bulk density at different location in boreholes.

BH. No.	Depth (m)	Bulk Density (g/cm ³)
1	4.0	1.8187
2	2.0	2.1626
6	2.0	1.8468
6	4.0	2.0104
8	6.0	2.1349
12	8.0	1.8950

Table No.(4.2) Bulk Density Test Results

4.5 Permeability Test

This test is conducted in an apparatus using the procedure of falling head Test method. Performed in accordance with ASTM D 5856. Samples for this results were compacted at the laboratory, Results for this test are shown in table (4.3).

BH.No.	Depth	Coefficient of Permeability (K) (cm/s)
1	3.0	0.02282
4	2.0	0.02322
7	6.0	0.022699
8	8.0	0.02426
9	10.0	0.02378
12	8.0	0.022794

Table (4.3) Results of permeability test

4.6- Free Swelling

Free Swell Index is the increase in volume of a soil on submergence in water, without any external constraints. Test procedure carried out with standard (BS 1377-1990). Results are shown in Table(4.4),

<i>BH.No.</i>	<i>Depth (m)</i>	<i>Initial Volume of Specimen (I)</i>	<i>Final Volume of Specimen (F)</i>	<i>Free Swell (F.S %)</i>
1	3.0	156.3	250	60
4	2.0	120.4	170	41.17
6	1.0	149.3	235	57.45
7	6.0	104.2	125	20.0
7	8.0	58.6	81	38.27
8	8.0	124.6	180	44.45
10	10.0	126.8	185	45.94
12	8.0	114.4	155	35.48
13	2.0	58.2	80	37.50

Table (4.4) Free Swelling Test Results

4.7- Swelling Pressure Test

The swelling pressure tests were conducted on undisturbed soil samples. The volume of the soil was kept constant in an odometer cell, while the soil was saturated with water during the test. The results are shown in Table (4.5).

Results reflected to very low of swelling pressures.

Borehole No.	Depth (m)	Initial moisture content (%)	Final moisture content (%)	Swelling Pressure Kpa	Plasticity Index (%)	Classification of the Samples
1	4.0m	25.94	28.40	20	41	CH
2	2.0m	14.50	15.54	0	17	SC
8	6.0m	9.21	14.14	10	20	SC
8	10.0m	10.23	15.12	0	16	SC
12	10.0m	10.42	15.97	10	18	SC

Table (4.5): Swelling Pressure Test Results

4.8 Consolidation Test

Consolidation tests provide information for use in evaluating the compressibility of the soils and estimating the settlement of foundations established on these soils. The consolidation tests were performed on clayey samples, according to the ASTM D 2435-03. Swelling pressure was conducted on the samples. Then the samples were loaded beyond the swelling pressure to allow consolidation to proceed. The results of these tests are shown in Appendix (C). Table (4.6) illustrate the summary results of consolidation parameters.

B.H. No.	Depth (m)	Initial moisture content	Final moisture content	Void ratio (e.)	Degree of saturation (S _r)	Pre consolidation Pressure (P _c)	Over Consolidation Ratio (OCR)
1	4.0	25.937	28.398	0.8696	80.5336	52	0.728
2	2.0	14.498	15.538	0.4295	91.13961	78	1.83
6	2.0	28.116	31.301	0.873	87.2755	90	2.48
6	4.0	10.419	14.196	0.4829	58.25096	90	1.14
8	6.0	9.211	14.136	0.3812	65.243	58	0.45
12	10.0	10.918	15.966	0.5732	49.0731	370	1.99

Table (4.6) Consolidation Test Parameters

4.9 Collapse Potential Test

4.9.1 Single Oedometer Collapse Test

The undisturbed soil specimen at natural moisture content loaded in the conventional oedometer to a stress level ranging between 200 KPa and 400 KPa, and then inundation by distilled water is applied to induce collapse. Abelev (1948) used stress level of 300 KPa and defined the collapse potential (I_c) as: $I_c = \Delta e_c / 1 + e_1$

Δe_c : change in void ratio resulting from saturation

e_1 : void ratio just before saturation recommended the using of stress level of 200 KPa, and calculate the collapse potential according to the following equation: $I_e = \Delta e_c / (1 + e_o)$

Δe_c : change in void ratio resulting from saturation

e_o : natural void ratio

The stress level of 200 KPa adopted by (ASTM D 5333-96, 2000) to classify the severity of the collapse problem. Since the idea behind this test is to predict the amount of deformation that a foundation may experience upon subsurface wetting; a loading to the anticipated field loading conditions is recommended. A results obtained from this test in boreholes are shown in Appendix(C-1) and Table(4.7)

BH. No.	Depth	e_o	e_1	e_2	C_p
1	3.0	0.7122	0.6320	0.6206	0.6664
2	4.0	0.4537	0.4105	0.3950	1.0704
4	2.0	0.4780	0.4349	0.4317	0.2118
7	6.0	0.5371	0.4734	0.4635	0.6467
7	8.0	0.6382	0.5781	0.5703	0.4743
8	8.0	0.2690	0.1720	0.1610	0.8684
8	10.0	0.3756	0.3467	0.3158	2.2499
9	10.0	0.3559	0.3185	0.3026	1.1712
11	6.0	0.4740	0.4509	0.4204	2.0706

Table(4.7) Single oedometer and Collapse potential Results

4.9.2 Double Oedometer Collapse Test

Two identical samples are placed in oedometers; one tested at in-situ natural moisture content, and the other is fully saturated before the test begins, and then subjected to identical loading.

Two stress versus strain curves are generated. The difference between the compression curves is the amount of deformation that would occur at any stress level at which the soil get saturated. Critical stress (σ_{cr}) represents the stress level at which the dry sample loose structure breaks down and beyond it the

two curves converge. This behavior could be explained also by that at high stress level, the limiting void ratio for the saturated sample is approached for particles packing. It is common for natural soil that the initial void ratio of the two samples are not initiating from the same point; in this case adjustment of the two curves according to the procedure proposed by shall be adopted for the normally and overconsolidated clays. Results for double oedometer collapse test are shown in Appendix(C-2).

4.10 Pin Hole Test

In the pinhole test, a sample of soil at its natural water content is compacted into a plastic cylinder. A hole is formed in the specimen by inserting a needle through the center of the specimen. Distilled water under specified heads flows through the hole in the specimen. The water is carefully observed for turbidity, and the flow rate is closely monitored to determine if the hole in the sample is enlarging by erosion. Dispersive clays will rapidly erode as water flows through the 1 millimeter hole under a small water head pressure. Rapid enlargement of the hole is reflected in an increasing flow rate and the turbidity of the collected water.

Test was according the BS 1377- part 5, for compacted disturbed samples in the laboratory. Results for samples are shown in Table (4.8).

Pinhole tests results are recorded and interpreted using the following system:

A rating of D-1 or D-2 indicates the soils are dispersive enough to require special designs if the soils must be used in the project.

A rating of ND-1 indicates the soil is not dispersive.

A rating of ND-2, ND-3, or ND-4 indicates the soils are slightly to moderately dispersive. Only one sample gave the result of D2, which indicate dispersive,

Other results are non dispersive.

Depth (m)	B.H NO.	Max Hydraulic Head Applied (mm)	Average of Last Head Rate of flow (ml/sec)	Classification
1	3	1020	3.13	ND2
2	4	1020	1.25	ND2
4	2	1020	2.56	ND1
6	1	1020	1.98	ND1
7	6	50	0.9	D2
8	8	50	0.9	ND4
9	10	50	0.8	ND4
11	6	50	0.8	ND4

Table (4.8) Pin hole Test Results

4.11 Sensitivity Tests

For many naturally deposited clayey soil, the unconfined compression strength (q_u) is greatly reduced when the soil is tested after remolding without any change in moisture content. This referred to as sensitivity and defined as

$$S_t = \frac{q_u(\text{undisturbed})}{q_u(\text{remolded})}$$

Results of samples for evaluation of sensitivity test are shown in Table(4.9).

BH. No.	Depth (m)	(q_u) unconfined compressive strength (undisturbed) (kpa)	(q_u) unconfined compressive strength (remolded) (kpa)	Sensitivity (S_t)	Description
1	3.0	4048.42	2146.58	1.886	Slightly sensitive
2	4.0	5305.22	2439.74	2.175	Medium sensitivity
7	6.0	2415.77	679.51	3.555	Medium sensitivity
8	8.0	20406.69	825.12	24.732	Medium quick
9	10.0	6784.28	1027.41	6.603	Very sensitive
12	8.0	344.43	586.44	0.587	Slightly sensitive

Table (4.9) Sensitivity Test Results

4.12 Chemical Tests

The test are preformed to determine the PH, organic matter, chloride, sulphate, PH of 1:2.5 soil/water suspension, Na⁺ and Mg⁺⁺).

Chemical tests were performed according to BS 1377, Part 3- 1990 on soil samples taken from different depths of borehole. The results are shown in tables at appendix(D).

5.0 Analysis of the Results:

5.1 General review

Problematic soils in Sudan include expansive soils, collapsible soils as well as dispersive soils. The increase in water content of the soil has caused some difficulties in problematic soils and this geotechnical problem may lead to reduction in shear strength or excessive deformations, and consequently increase or decrease in soil thickness or volume. Knowledge of collapsible soils is not widely covered in Sudan, i.e, Generally, the areas where most of development projects were constructed didn't include collapsible soils. This is

why many engineers were not exposed to this type of soils. However, now collapsible soils are been encountered more and new studies have been published as ref. "An Experimental Study on the Identification and Classification of Collapse Potential of Some Soils in Sudan", (E.M.Ali and M.A. Osman) 18th International Conference on Soil Mechanics and Geotechnical Engineering, Paris 2013).

Collapsible soils have high porosity rates and they are subset of unsaturated soils. In general, collapsibility in soils occurs when fabric of soils with partial saturation and metastable cause the formation of metastable structure under constant stress, and together with increase in water content high inter-aggregate suction or cementing agent becomes weaker or disappears and consequently causes soil structure to be collapsed. And this will cause reduction in volume and sudden collapse of the soil, which is possible with or without applying additional load. Therefore, collapsibility is possible either in the form of increase in water content or simultaneously together with applying the load.

Internationally such soils have recently been studied. These are soils that are found in arid and semiarid zoned and are now studied as partially saturated media.

5.2 Origins of Collapsible Soils

Collapsible soils include Aeolian, alluvial, colluvial, residual deposits as well as volcanic tuff material. Loess is the most known collapsible sand deposit; however compacted fill materials have been reported in the literature. Indiana, USA is one location where compacted fill has been studied and documented. (Identification and Behavior of Collapsible Soils, Joint Transportation Research Program, Purdue University).

5.3 Collapsible Soil Behavior:

Collapse soil is distinguished by high voids with low degree of saturation. In situ strength of natural condition may be high. Collapsible soils experience significant volume change as the moisture content increase whether associated with changes in confining pressures or not. Such volume changes if not

considered in the geotechnical studies of the project will lead to differential settlements and major risks to the project.

5.4 Identification of Collapsible Soil

To be able to identify such soils, many methods were introduced. Table(5.1) gives a summary of some of the identification methods.

No.	Investigator , year	Criteria
1	Abelev,1948	$\delta_s=(\Delta e/1+e_L)$ Collapse is probable when: $\delta_s > 2\%$
2	Denisov, 1951	$K=e_L/e_o$ If $k = 0.5-0.75$; highly Collapsible If $k = 1.0$; non Collapsible loam If $k = 1.5-2.0$; non Collapsible soil
3	Prikloński, 1952	$K_D=(N.M.C-P.L)/PI$ If $k_D < 0$; highly Collapsible soil If $k_D > 0.5$; non Collapsible loam If $k_D > 1.0$; Swelling soil
4	Clevenger, 1958	$\gamma_{dry} < 12.6 \text{ kn/m}^3$; Significant Settlement $\gamma_{dry} < 14.1 \text{ kn/m}^3$; transitional Settlement
5	Gibbs and Bara, 1962	Collapse is probable when $\gamma_{dry} < 162.3/(1+0.026*L.L) \text{ Ib/ft}^3$ or when: $e_o > 2.6*L.L/100$
6	Soviet Building Code,1962	Collapse is probable when :is $S > 60\%$ and $(e_o-e_L)/(1+e_o) > -0.10$
7	Feda 1964 , 1966	$K_L=(N.M.C/S)-(PL/PI)$ If $K_L > 0.85$; Collapseible Soil
8	Handy, 1973	Clay Content $< 16\%$; high probability for collapse $24\% >$ Clay Content $> 16\%$; probably collapsible $32\% >$ Clay Content $> 25\%$; probability of collapse of less than 50% Clay Content $> 32\%$; non collapsible
9	Zur and wiseman 1973	$\gamma_{dry} / \gamma_{dry \text{ L.L}} < 1.1$; Soil prone to collapse $\gamma_{dry} / \gamma_{dry \text{ L.L}} < 1.3$; Soil prone to swell

Table (5.1) Summary of Identification methods for collapse soil

5.5 Evaluation of Collapse Potential

A simplification of the volume change in the consolidation e-log-p graph given in Fig(3) leads to

$$C_p = (e_2 - e_1) / (1 + e_0)$$

Where

C_p : Collapse potential

e_0 : initial void ratio

e_1 : void ratio

e_2 : void ratio




Fig.(3) Nature of variation of void ratio with pressure for a collapsing soil

5.6 Classification of Collapsible soil

Classification of collapsible soils as non-collapsible, low, medium, high, very high collapsibility potential as given in Table (5.2).

C_p : Collapse Classification

Collapsibility degree	Percentage of soil collapsibility
0	Non-collapsible
0.1- 2	Low collapsible
2.1- 6	medium collapsible
6.1- 10	Almost high collapsible
>10	High collapsible

Table (5.2) Collapse soil classification

5.7 Use of Collapsible Soils as A compaction Fill Material

Some compacted fill materials may have some collapse potential and the engineer may be compelled to use them. A detailed study was carried out for the Indiana loess (identification and Behavior of collapsible soils, Joint Transportation Research Program, Purdue University). The recommendations of this study were:

- 1- Compaction effort should be high as needed.
- 2- Compaction should be carried out wet of optimum.
- 3- Preloading of compacted fill may be considered
- 4- Sometime stabilization or grouting, maybe appropriate.

Estimates of collapse of a compacted fill due to increase in moisture content may be estimated from C_p values determined from results of single or double oedometer tests.

5.8 The Actual Situation in Kosti Thermal Power Station, Rabak is the Following:

- 1- For all foundation units in the power plant main elements and river water intake pump house, the existing expansive soils were excavated and main foundations are rested on the natural non expansive soil. But the backfilling was done using local fill materials from borrow areas, located outside power station area. However this fill, was not identified originally as possessing any collapse potential. The fill was placed and compacted by the client. The client has all the details about fill material, compaction testing, compaction operation and quality control.
- 2- The compacted backfill area was exposed for some periods of time and the rainy season may have caused wetting of those fills or other sources of moisture may also have contributed to wetting. The in situ moisture content and consequently the degree of saturation of subsoil as shown in soil profile is high.

- 3- After the installation, differential settlement were observed at few location in floors resting on compacted backfill. It is expected that collapse may have occurred.
- 4- The current soil investigation was carried out in the soil that has already experienced significant volume change due to soil collapse. The client has determined the number of borehole to be drilled and locations and depth. Laboratory test were carried out on collected soil samples. Few samples slipped during collection and at depths sample quantity is very less due to which some tests were carried out on the sample collected from other depths than those specified by the client.

5.9 Identification of Collapsible Soil

Due to the fact that compacted fill has already collapsed and experienced settlement it is expected that volumetric, density, moisture content characteristics cannot be used fully to identify the potential of the soil.

However published literature about collapse behavior of compacted fill in Indiana has indicated that plot fall between A-Line & U-Line as shown in figure (6).

The plot of LL against PL for Kosti power station, Rabak are shown in same fig. which shows very high level of consistency with the result from Indiana.





Fig.(6) Behavior of compacted fill in Indiana, A- Line & U- Line



The grain size in Indiana and other location indicate that for (CL) compacted fill, clay content between (10 – 30 %) is critical for collapse potential. When silt is mixed with clay at about equal value the potential of collapse is greater. For sandy clay the same condition exist.

5.10 Evaluation

We carried out oedemeter test to determine the collapse potential. The oedemeter test carried out by single and double oedemeter type.

Because of the reason mentioned about the collapse in field, the result of the oedemeter test gave values that are small compared with the actual value if collapse did not happen earlier.

Results from the single oedometer are given in table (4.7) and show that the collapse potential vary between (1.0 – 2.0) with indicate low to medium collapse potential.

For the double oedemeter test two tests were carried out for undisturbed samples one sample was conduct without adding any more water in the test. In second sample water was added from the beginning. Five tests were carried out with double oedemeter method, it is noted that the initial moister content for both test were not equal although the samples were physically near to each other. This may be due to heterogeneity in the soil or due to stress release or other sample disturbance. This condition was reported also in Indiana soil for samples that where treatment from compacted fill materials. (Identification and Behavior of Collapsible Soils, Joint Transportation Research Program, Purdue University).

In order to asses the collapse potential of the original fill material from borrow areas, the two samples given by he client were tested and the report is furnished in appendix (F).

5.11 Collapse Classification

According to table (5.2) and based on the assumption and results mentioned previously, the collapse potential of the backfill soil at site is expected to be in

the range C_p value from (1 to 2). These low values may be due to the reason that existing backfill has already experienced significant volume change due to soil collapse.

But the C_p values of the original soil from borrow area ranges between 1 to 7 (Ref. Appendix (F) Table.3). However, the C_p Values of this soil compacted at 8% moisture content (which is less by about 2% – 3% from O.M.C) is ranging between 3 to 7 which shows medium to high collapsible nature of the soil.

5.12 Data About the Fill Material

The client has supplied ESD with some data about the fill materials. This included proctor compaction test and quality control records for fill in river water intake pump house area. Presentation of the results of the compaction controll is given in figure (7). This shows the moisture content values of different layers with the average moisture content (amc) \pm standard deviation value.

The optimum moisture content from the compaction test is also shown. The final moisture content determined by ESD also, plotted for all boreholes in the project, it's clear that;

1. Compaction was carried out at dry than optimum moisture content.
2. Moisture content has increased directly after wards.

6.0 Discussion of the Results:

After review of all the results of this study, the consultant believes that the major cause of the settlement is due to the soil collapse induced by increase of moisture content in compacted fill materials.

6.1 Proposal of Remedial Measure

For the existing condition of the installed equipment/ground floor slab already constructed in power plant, one of the remedial option is to use soil

stabilization with grouting to stabilize the fill material. This is a specialized procedure calling for experienced sub contractor in this field.

Second option is to remove the equipments and floors, then recompact the exsiting fill at high moisture content, so that the collapse potential of the fill soil is minimuzed.

Third option is to excavate the fill and make a new fill with non collapsible, non expansive and non dispersive fill materials.The fill should be compacted at the wet than optimum moisture content and high compacted effort. This should be based on detailed study of compaction process of the fill materials.

Drainage of the site should be a high priority, so that rain or other site sources of water should not cause problems to the fills.

7.0 Conclusion

A geotechnical of investigation was carried out at Kosti power plant, Rabak to study the settlement after construction. It's found that the backfill soil below ground floor level was soaked and moisture content increased considerably. It's believed that the major cause of the settelment is collapse of the fill material. This material has not been identified to have collapse potential prior to construction. The compaction operation did not address this issue. The fact, that the compaction was carried dry of optimum moisture content values and surface with poor drainage led to collapse induced by change in moisture content.


Three remedial options are given in the report:

1. Stablization by cement grouting carried out by highly experienced specialized subcontractor.
2. Remove the equipments and floors, then compact the exsiting fill at high moisture content.
3. Excavate the fill and make a new fill with non collapsible, non expansive and non dispersive fill materials.

This report is based on laboratory and field tests made on boreholes that were drilled in the present site and two soil samples from borrow areas. ESD is not responsible for soil conditions at site different from those exposed at the boreholes drilled in this investigation.

8. References:

- 1- Joesph E. Bowles, Foundation Analysis and Design, Fifth Edition, 1994
- 2- Muni Budhu, Soil Mechanics & Foundations, 2000, John Wiley & Sons, Inc.
- 3- El Howayek, A., P. Huang, R. Bisnett, and M. C. Santagata. Identification and Behavior of Collapsible Soils. Publication FHWA/IN/JTRP-2011/12. Joint Transportation Research Program, Indiana Department of Transportation and Purdue University, West Lafayette, Indiana, 2011.
- 4- Engineering and Design - Settlement Analysis, 30 September 1990, Department of the Army, U.S. Army Corps of Engineers, Washington, DC 20314-1000.
- 5- Materials Testing, Field Manual 5-472*, NAVFAC M0 330, AFJMAN 32-1221(I), Headquarters Department of the Army Department of the Navy Department of the Air Force Washington, DC, 27 October 1999.
- 6- American Society for Testing and Materials (ASTM).
- 7- BS 5930: 1999: Code of Practice for Site Investigations
- 8- BS 1377: 1990: Methods of Test for Soils for Civil Engineering Purposes
- 9- N.E.Simons and B.K.Menzies, A Short Course in Foundation Engineering





APPENDIX (A)
LOCATION OF BOREHOLES
AND
SUMMARY OF
LABORATORY TEST RESULTS




FIGURES (1)
LOCATION OF BOREHOLES

**Kosti Thermal Power Station
Power Station Area
Location of Boreholes**



**Kosti Thermal Power Station
Pump Station Area
Location of Boreholes**




© 2013 Google
Image © 2013 DigitalGlobe

Google earth

**Kosti Thermal Power Station
Pipe Line Area
Location of Boreholes**





BH-6


BH-5

BH-4

BH-3

BH-2

BH-1



RIVER WATER INTAKE PUMP HOUSE

PLAN AT EL.(±)0.00M.




FIGURE (2)
BOREHOLE LOGS AND SUMMARY OF
LABORATORY TEST RESULTS

Soil Profile															
Kosti Thermal Power Station															
Power Station Area															
B.H # 1															
Coordinates: E: 480719 N: 1460153															
Starting date: 24/11/2013															
Finishing date: 24/11/2013															
Elevation : From the existing ground surface level															
Ground Water Level : Not observed															
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result						Remarks
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value	pen. inch		
									6	3	3	3			
1.0	Dark brown silty clay of low plasticity	CL	37	21	16		9.51	54.14							UDS
2.0	Light grey moist poorly graded silty sand	SP-SM		N.P	N.P		2.34	5.64							UDS
3.0	Dark grey silty clay of high plasticity	CH	68	25	43	19.07	24.87	84.72							UDS
4.0			67	26	41	19.00	25.28	74.42							UDS
Bottom of borehole @ 4.0m															

Soil Profile																
Kosti Thermal Power Station																
Power Station Area																
B.H # 2			Coordinates: E: 480705 N: 1460207			Starting date: 24/11/2013			Finishing date: 24/11/2013							
Elevation : From the existing ground surface level			Ground Water Level : Not observed													
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result						Remarks	
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value				pen. inch
								6	3	3	3	3	3			
1.0	Dark brown dry silty clay of low plasticity	CL	45	19	26			58.13								
2.0	Light grey moist clayey sand	SC	39	22	17	11.14	14.67	41.61								UDS
3.0	Geryish brown moist silty clay of high plasticity	CH	68	27	41	15.0	27.35	80.53								UDS
4.0	Geryish brown moist clayey sand	SC	44	18	26		9.89	29.21								UDS

Bottom of borehole @ 4.0m

Soil Profile														
Kosti Thermal Power Station														
Power Station Area														
B.H # 3		Coordinates: E: 480877 N: 1460040		Starting date: 25/11/2013		Finishing date: 25/11/2013								
Elevation : From the existing ground surface level		Ground Water Level: Not observed												
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result				Remarks	
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value		pen. inch
1.0	Soft dark brown moist silty clay of low plasticity	CL	45	18	27	12.29								
2.0			1	1	1	3								
3.0														
4.0	Very loose dark brown moist clayey sand	SC	37	19	20	9.71	45.72	1	1	1	1	4		
5.0			40	18	22	10.00	29.69							
6.0			45	23	22	9.21	33.54	2	1	1	1	4		
7.0	Soft dark brown silty clay of low plasticity .	CL	43	21	22	9.86	59.77	2	1	1	1	3	UDS (Empty)	
8.0			48	26	22	7.71	36.66							
9.0	Soft dark brown silty clay of low plasticity .	CL	43	23	20	9.14	53.23	2	1	1	1	3	UDS (Empty)	
10.0														UDS (Empty)
Bottom of borehole @ 10.0m														

Soil Profile															
Kosti Thermal Power Station															
Power Station Area															
B.H # 4			Coordinates: E: 480944 N: 1469983			Starting date: 26/11/2013			Finishing date: 26/11/2013						
Elevation : From the existing ground surface level			Ground Water Level : Not observed												
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result						
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value			pen. inch
								6	3	3	3	3	3	3	
1.0	Dark brown moist clayey sand														
2.0	Light grey moist poorly graded silty sand	SC	41	19	22	11.71	9.54	21.44							UDS
3.0															
4.0															UDS (Empty)
Bottom of borehole @ 4.0m															

Soil Profile																		
Kosti Thermal Power Station																		
Power Station Area																		
B.H # 5																		
Elevation : From the existing ground surface level																		
Coordinates: E: 480920 N:1460080																		
Ground Water Level :Not observed																		
Starting date: 25/11/2013																		
Finishing date: 25/11/2013																		
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result						Remarks			
			L.L %	P.L %	P.I %				Blows for inch			N Value	pen. inch					
1.0	Loose dark brown moist clayey sand																	
2.0																		
3.0																		
4.0																		
5.0																		
6.0	Dark brown moist clayey sand	SC	48	20	28	10.79		35.93										
7.0																		
8.0																		
9.0	Same but poorly and dense	SP-SC																
10.0																		
	Same but very dense		20	6	14			39.07										
Bottom of borehole @ 10.0m																		

Soil Profile																
Kosti Thermal Power Station																
Power Station Area																
B.H # 6				Coordinates: E: 480988 N: 1460171				Starting date: 26/11/2013				Finishing date: 26/11/2013				
Elevation : From the existing ground surface level				Ground Water Level : Not observed												
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result						Remarks	
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value				pen. inch
								6	3	3	3	3	3	3		
1.0	Dark brown moist clayey sand															UDS (Empty)
2.0	Light grey moist silty clay of high plasticity	CH	75	30	45	20.00	29.25									UDS
3.0	Medium dense greyish brown moist clayey sand	SC	43	20	23	11.38		6	5	4	4	3	16			UDS (Empty)
4.0			36	16	20	10.57	9.73									UDS

Bottom of borehole @ 4.0m

Soil Profile															
Kosti Thermal Power Station															
Pump Station Area															
Coordinates: E: 475637 N: 1452202															
Ground Water Level : Not observed															
Starting date: 19/11/2013															
Finishing date: 19/11/2013															
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	%pass sieve #200	SPT Result				Remarks		
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value		pen. inch	
								6	3	3	3				
1.0	Dark brown moist clayey sand	SC													
2.0	Light grey moist poorly graded silty sand					10									
3.0															
4.0															
5.0															
6.0															
7.0															
8.0	Dark brown silty clay of low plasticity.	CL	32	16	16	9.14	7.59	56.61						UDS	
9.0															
10.0	Dark brown clayey sand	SC	36	20	16	8.64	9.67	39.08						UDS	
Bottom of borehole @ 10.0m															

Soil Profile															
Kosti Thermal Power Station															
Pump Station Area															
Coordinates: E: 475649 N: 1452204															
Starting date: 22/11/2013															
Finishing date: 23/11/2013															
Ground Water Level : Not observed															
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result					Remarks	
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value	pen. inch		
								6	3	3	3	3			
1.0	Loose dark brown moist clayey sand	SC													
2.0									2	1	2	1	4		
3.0			same but medium dense												
4.0										6	4	5	4	6	19
5.0			same but dense												
6.0										9	9	10	9	11	39
7.0			same but very dense												
8.0															
9.0															
10.0			same but greyish brown												
			39	20	19	8.00	41.79	24	13	14	17	7	51	UDS (Empty)	
			41	22	19		29.06							UDS	

Bottom of borehole @ 10.0m

Soil Profile																	
Kosti Thermal Power Station																	
Pump Station Area																	
Coordinates: E: 474670 N: 1452189																	
Ground Water Level : Not observed																	
Starting date: 21/11/2013																	
Finishing date: 22/11/2013																	
B.H # 10																	
Elevation : From the existing ground surface level																	
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result					Remarks			
			L.L.%	P.L.%	P.I.%				Blows for inch			N Value	pen. inch				
									6	3	3	3					
1.0	Very dense dark brown moist clayey sand	SC															
2.0																	
3.0											20	12	13	16	10	51	
4.0																	
5.0																	
6.0																	
7.0																	UDS
8.0	Greyish brown moist silty clay of low plasticity .	CL															
9.0																	
10.0																	UDS

Bottom of borehole @ 10.0m

Soil Profile																
Kosti Thermal Power Station																
Pump Station Area																
B.H # 11		Coordinates: E: 474667 N: 1452182		Starting date: 23/11/2013		Finishing date: 23/11/2013										
Elevation : From the existing ground surface level		Ground Water Level : 3.0m														
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result					Remarks		
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value	pen. inch			
1.0	Loose dark brown moist clayey sand	SC														
2.0																
3.0																
4.0																
5.0																
6.0																
6.0	Dark brown moist silty clay of low plasticity	CL	38	19	19	9.14	15.26	51.41							UDS	
7.0																
8.0	Dark brown moist clayey sand	SC	28	18	10	8.00	8.09	45.91							UDS	
9.0																
10.0	same but greyish brown		36	19	17	7.86	10.34	35.05							UDS	
Bottom of borehole @ 10.0m																


Soil Profile															
Kosti Thermal Power Station															
Pump Station Area															
B.H # 12		Coordinates: E: 474635 N: 1452175		Starting date: 20/11/2013		Finishing date: 20/11/2013									
Elevation : From the existing ground surface level		Ground Water Level : Not observed													
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result				Remarks		
			L.L. %	P.L. %	P.I. %				Blows for inch			N Value		pen. inch	
								6	3	3	3				
1.0	Dark brown moist clayey sandy gravel														
2.0															
3.0															
4.0															
5.0															
6.0	Light brown clayey sand	SC	40	18	22	8.79	11.40	32.55						UDS	
7.0															
8.0	same but greyish brown		37	19	18	5.34	13.02	43.25						UDS	
9.0															
10.0															UDS (Empty)
Bottom of borehole @ 10.0m															

Soil Profile																
Kosti Thermal Power Station																
Pipe Line Area																
Coordinates: E: 480988 N: 1460171																
Starting date: 24/11/2013																
Finishing date: 24/11/2013																
B.H # 13																
Elevation : From the existing ground surface level																
Ground Water Level : Not observed																
Depth (m)	Description	Group Symbol	Atterberg Limits			Shrinkage Limit (%)	N.M.C %	% pass sieve #200	SPT Result						Remarks	
			L.L. %	P.L. %	P.I. %				Blows for inch	N Value	pen. inch	6	3	3		3
1.0	Reddish brown poorly graded silty sand	SP-SM		NP	NP		9.12									
2.0	Same but loose.	SM		NP	NP		14.78	1	1	2	1		4			UDS (Empty)
3.0				NP	NP		17.90	1	1	1	1		3			UDS (Empty)
4.0	Medium dense light brown clayey sand	SC	23	15	8	2.07	29.25	5	3	5	5	6	19			UDS (Empty)
Bottom of borehole @ 4.0m																




APPENDIX (B-1)
GRAIN SIZE DISTRIBUTION RESULTS
SIEVE ANALYSIS TESTT


**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 1**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 2**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 3(A)**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 3(B)**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 4**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 5**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 6**




Grain Size Distribution Curve
Kosti Thermal Power Station
Borehole No. 7




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 8**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 9**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 10**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No.11**



**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 12**




**Grain Size Distribution Curve
 Kosti Thermal Power Station
 Borehole No. 13**






APPENDIX (B-2)
GRAIN SIZE DISTRIBUTION RESULTS
HYDROMETER TESTT


**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 1
 Depth: 1.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 1
 Depth: 3.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 2
 Depth: 2.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 4
 Depth: 2.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 6
 Depth: 2.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 7
 Depth: 6.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 7
 Depth: 8.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 8
 Depth: 8.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 9
 Depth: 10.0m**



**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 11
 Depth: 8.0m**




**Kosti Thermal Power Station
 Hydrometer Test Curve
 BH. No. 12
 Depth: 8.0m**






APPENDIX (C)
CONSOLIDATION TEST RESULTS


**Kosti Thermal Power Station
 B.H No.1
 Depth: 4.0m
 Consolidation Curve**




**Kosti Thermal Power Station
 B.H No. 2
 Depth: 2.0m
 Consolidation Curve**




**Kosti Thermal Power Station
 B.H No.6
 Depth: 2.0m
 Consolidation Curve**




**Kosti Thermal Power Station
 B.H No. 6
 Depth: 4.0m
 Consolidation Curve**



**Kosti Thermal Power Station
 B.H No. 8
 Depth: 6.0m
 Consolidation Curve**



**Kosti Thermal Power Station
 B.H No. 12
 Depth: 10.0m
 Consolidation Curve**






APPENDIX (C-1)
SINGLE OEDOMETER TEST RESULTS

Sample of Single Oedometer Test

Sample of Calculations:

1. BH.No.1 Depth 1.5m



Calculation:

For $e_o = 0.7122$

$$C_p(\%) = \frac{(e_2 - e_1)}{1 + e_o} = \frac{(0.6320 - 0.6206)}{1 + 0.7122} \times 100 = 0.67$$


where e_o = natural void ratio and

$(e_2 - e_1)$: vertical strain


2. Table Below shows the results of C_p in single Oedometer Test

BH. No.	Depth	e_o	e_1	e_2	$C_p(\%)$
2	4	0.4537	0.4105	0.395	1.07
4	2	0.478	0.4349	0.4317	0.22
7	6	0.5371	0.4734	0.4635	0.64
7	8	0.6382	0.5781	0.5703	0.48
8	8	0.269	0.172	0.161	0.87
8	10	0.3756	0.3467	0.3158	2.25
9	10	0.3559	0.3185	0.3026	1.17
11	6	0.474	0.4509	0.4204	2.07


**Kosti Thermal Power Station
 B.H NO. 1
 Depth: 3.0m
 Single Oedometer Collapse Curve**




**Kosti Thermal Power Station
 B.H No. 2
 Depth: 4.0m
 Single Oedometer Collapse Curve**




**Kosti Thermal Power Station
 B.H NO. 4
 Depth: 2.0m
 Single Oedometer Collapse Curve**




Kosti Thermal Power Station
 B.H No. 7
 Depth: 6.0m
 Single Oedometer Collapse Curve




**Kosti Thermal Power Station
 B.H No. 7
 Depth: 8.0m
 Single Oedometer Collapse Curve**




Kosti Thermal Power Station
 B.H No. 8
 Depth: 8.0m
 Single Oedometer Collapse Curve




Kosti Thermal Power Station
 B.H No. 8
 Depth: 10.0m
 Single Oedometer Collapse Curve



**Kosti Thermal Power Station
 B.H No. 9
 Depth: 10.0m
 Single Oedometer Collapse Curve**




Kosti Thermal Power Station
 B.H No. 11
 Depth: 6.0m
 Single Oedometer Collapse Curve






APPENDIX (C-2)
DOUBLE OEDOMETER TEST RESULTS


**Kosti Thermal Power Station
 B.H No. 2
 Depth: 4.0m
 Double Oedometer Collapse Curve**




Kosti Thermal Power Station
 B.H No. 9
 Depth: 10.0m
 Double Oedometer Collapse Curve



Kosti Thermal Power Station
 B.H No. 11
 Depth: 6.0m
 Double Oedometer Collapse Curve



Kosti Thermal Power Station
 B.H NO. 12
 Depth: 8.0m
 Double Oedometer Collapse Curve





APPENDIX (D)
CHEMICAL ANALYSIS TEST RESULTS

Chemical Test Report

KostiThermal Power Station

Chemical and Physical Analysis

Methods of Tests: BS 1377 - Part 3 -1990

B.H. No.	Depth	T.Hardness	Calcium	Magnesium	Sodium	Unit
1	3.0	680	204	40.8	28.13	Mg/l
1	4.0	650	260	NIL	24.65	Mg/l
2	2.0	110	NIL	26.4	14.43	Mg/l
3	2.0	80	NIL	19.2	14.99	Mg/l
3	9.0	80	NIL	19.8	14.03	Mg/l
4	2.0	150	12	28.8	21.76	Mg/l
4	4.0	190	16	36	13.7	Mg/l
5	6.0	60	NIL	14.4	13.07	Mg/l
6	1.0	280	100	7.2	22	Mg/l
6	4.0	110	24	12	20.8	Mg/l
7	6.0	100	NIL	24	15.71	Mg/l
7	8.0	100	NIL	24	14.75	Mg/l
7	10.0	90	NIL	21.6	14.67	Mg/l
8	6.0	140	NIL	30.6	17.15	Mg/l
8	8.0	80	NIL	19.2	15.79	Mg/l
8	10.0	90	NIL	21.6	15.07	Mg/l
9	10.0	100	NIL	24	15.39	Mg/l
10	6.0	70	NIL	16.8	16.83	Mg/l
10	10.0	240	12	50.4	16.91	Mg/l
11	10.0	170	NIL	40.8	14.11	Mg/l
11	6.0	100	NIL	24	14.92	Mg/l
12	6.0	90	NIL	21.6	14.43	Mg/l
12	8.0	100	12	16.8	14.91	Mg/l
12	10.0	90	NIL	21.6	16.27	Mg/l
13	2.0	100	NIL	24	14.92	Mg/l

Table (D - 1) Chemical Tests Results

Chemical Test Report

KostiThermal Power Station

Chemical and Physical Analysis

Methods of Tests: BS 1377 - Part 3 -1990

B.H. No.	Depth	PH	PH 1:2.5 soil/Water	Sulphate	Chloride	Organic Matter
1	3.0	8.18	8.54	0.0856	0.0142	2.7894
1	4.0	8.29	8.56	0.0687	0.0689	2.9068
2	2.0	7.9	8.3	0.0514	0.0142	1.3284
3	2.0	7.92	7.15	0.0343	0.0142	1.3178
3	9.0	8.22	7.17	0.0341	0.0352	1.2164
4	2.0	8.63	7.25	0.0343	0.0312	2.6174
4	4.0	8.4	8.15	0.0685	0.0284	2.0146
5	6.0	7.98	6.55	0.0685	0.0173	3.835
6	1.0	7.25	6.88	0.1714	0.0312	4.8281
6	4.0	8.2	9.25	0.0513	0.0355	4.6853
7	6.0	7.68	8.69	0.0339	0.0173	1.1982
7	8.0	7.85	8.05	0.0342	0.0242	1.145
7	10.0	7.86	8.2	0.0857	0.0173	0.8446
8	6.0	7.68	7.76	0.0343	0.0379	2.13
8	8.0	7.6	7.7	0.0684	0.0312	2.3886
8	10.0	7.7	7.92	0.0685	0.0379	2.01
9	10.0	8.79	8.86	0.0343	0.0213	2.5838
10	6.0	8.7	8.69	0.0513	0.0379	4.7553
10	10.0	9.3	9.04	0.0685	0.0448	1.9028
11	10.0	8.82	7.65	0.0343	0.0379	3.2761
11	6.0	8.95	9.26	0.0342	0.0158	1.986
12	6.0	8.07	7.76	0.0514	0.0379	2.00887
12	8.0	7.9	7.75	0.0514	0.0448	3.8077
12	10.0	7.9	7.86	0.0857	0.0312	2.0296
13	2.0	9.14	8.8	0.0342	0.0071	0.5596

Table (D - 1) Chemical Tests Results



APPENDIX (E)
TABLES AND TESTS RESULTS

- **Specific Gravity**

BH. No.	Depth (m)	Specific Gravity
1	3.0	2.78
2	2.0	2.82
4	2.0	2.74
7	8.0	2.72
7	6.0	2.69
8	8.0	2.86
9	10.0	2.85
12	8.0	2.78

Table No.(4.1) Specific Gravity Test Results

- **Bulk Density Test**

BH. No.	Depth (m)	Bulk Density (g/cm ³)
1	4.0	1.8187
2	2.0	2.1626
6	2.0	1.8468
6	4.0	2.0104
8	6.0	2.1349
12	8.0	1.8950

Table No.(4.2) Bulk Density Test Results

- **Permeability Test**

BH.No.	Depth	Coefficient of Permeability (K) (cm/s)
1	3.0	0.02282
4	2.0	0.02322
7	6.0	0.022699
8	8.0	0.02426
9	10.0	0.02378
12	8.0	0.022794

Table (4.3) Results of permeability test

• **Free Swelling**

<i>BH.No.</i>	<i>Depth (m)</i>	<i>Initial Volume of Specimen (I)</i>	<i>Final Volume of Specimen (F)</i>	<i>Free Swell (F.S %)</i>
1	3.0	156.3	250	60
4	2.0	120.4	170	41.17
6	1.0	149.3	235	57.45
7	6.0	104.2	125	20.0
7	8.0	58.6	81	38.27
8	8.0	124.6	180	44.45
10	10.0	126.8	185	45.94
12	8.0	114.4	155	35.48
13	2.0	58.2	80	37.50

Table (4.4) Free Swelling Test Results

• **Swelling Pressure Test**

Borehole No.	Depth (m)	Initial moisture content (%)	Final moisture content (%)	Swelling Pressure Kpa	Plasticity Index (%)	Classification of the Samples
1	4.0m	25.94	28.40	20	41	CH
2	2.0m	14.50	15.54	0	17	SC
8	6.0m	9.21	14.14	10	20	SC
8	10.0m	10.23	15.12	0	16	SC
12	10.0m	10.42	15.97	10	18	SC

Table (4.5): Swelling Pressure Test Results

• **Pin hole Test**

Depth (m)	B.H NO.	Max Hydraulic Head Applied (mm)	Average of Last Head Rate of flow (ml/sec)	Classification
1	3	1020	3.13	ND2
2	4	1020	1.25	ND2
4	2	1020	2.56	ND1
6	1	1020	1.98	ND1
7	6	50	0.9	D2
8	8	50	0.9	ND4
9	10	50	0.8	ND4
11	6	50	0.8	ND4

Table (4.8) Pin hole Test Results

• **Sensitivity Tests**

BH. No.	Depth (m)	(q_u) unconfined compressive strength (undisturbed) (kpa)	(q_u) unconfined compressive strength (remolded) (kpa)	Sensitivity (S_t)	Description
1	3.0	4048.42	2146.58	1.886	Slightly sensitive
2	4.0	5305.22	2439.74	2.175	Medium sensitivity
7	6.0	2415.77	679.51	3.555	Medium sensitivity
8	8.0	20406.69	825.12	24.732	Medium quick
9	10.0	6784.28	1027.41	6.603	Very sensitive
12	8.0	344.43	586.44	0.587	Slightly sensitive

Table (4.9) Sensitivity Test Results

• **Summary of Identification Methods for Collapse Soil**

No.	Investigator , year	Criteria
1	Abelev,1948	$\delta_s = (\Delta e / (1 + e_L))$ Collapse is probable when: $\delta_s > 2\%$
2	Denisov, 1951	$K = e_L / e_o$ If $k = 0.5-0.75$; highly Collapsible If $k = 1.0$; non Collapsible loam If $k = 1.5-2.0$; non Collapsible soil
3	Priklonski, 1952	$K_D = (N.M.C - P.L) / PI$ If $k_D < 0$; highly Collapsible soil If $k_D > 0.5$; non Collapsible loam If $k_D > 1.0$; Swelling soil
4	Clevenger, 1958	$\gamma_{dry} < 12.6 \text{ kn/m}^3$; Significant Settlement $\gamma_{dry} < 14.1 \text{ kn/m}^3$; transitional Settlement
5	Gibbs and Bara, 1962	Collapse is probable when $\gamma_{dry} < 162.3 / (1 + 0.026 * L.L) \text{ Ib/ft}^3$ or when: $e_o > 2.6 * L.L / 100$
6	Soviet Building Code,1962	Collapse is probable when :is $S > 60\%$ and $(e_o - e_L) / (1 + e_o) > -0.10$
7	Feda 1964 , 1966	$K_L = (N.M.C/S) - (PL/PI)$ If $K_L > 0.85$; Collapsible Soil
8	Handy, 1973	Clay Content $< 16\%$; high probability for collapse $24\% >$ Clay Content $> 16\%$; probably collapsible $32\% >$ Clay Content $> 25\%$; probability of collapse of less than 50% Clay Content $> 32\%$; non collapsible
9	Zur and wiseman 1973	$\gamma_{dry} / \gamma_{dry L.L} < 1.1$; Soil prone to collapse $\gamma_{dry} / \gamma_{dry L.L} < 1.3$; Soil prone to swell

Table (5.1) Summary of Identification methods for collapse soil



APPENDIX (F)
SAMPLES CLASSIFICATION ON BORROW AREA SOIL SAMPLES
GIVEN BY BHEL MARKED SPILE AND PCL

Introduction:

The client has selected two samples from borrow areas, PCL and SPILE. Tests are carried out on these two samples for Atterberg limit, Sieve analysis, Hydrometer, Specific Gravity, Compaction Test, Single and Double Oedometer Test.

Classification Results for these samples are shown in table (1) below.

Sample No.	Description	LL%	PL%	PI%	%Pass Sieve #200	Classification of sample	MDD g/cm ³	OMC %
SPILE	Dark brown clayey gravel	40	23	17	24.04	GC	2.05	10.4
PCL	Dark brown to light clayey sand	38	22	16	40.50	SC	1.97	11.4

Table (1) Soil Samples Classification

The classificatoion results are shown in table (1) illustrated, soil is dark brown clayey gravel (GC) for SPILE sample and dark to light brown clayey sand (SC) for PCL sample. Optimum moisture content is 10.4% for SPILE sample and 11.4% for PCL sample in compaction test results which are shown in Appendix A. Also, maximum dry density equal 2.05g/cm³ and 1.97g/cm³ for SPILE sample and PCL sample respectively.

At SPILE sample, the results gave liquid limit value around 40% and plastic index is 17%. At PCL, results gave liquid limit value is 38% and plastic index around 16%, these results of Atterberge limits indicate possibility of occurrence medium potential for swelling.

Grain size distribution are the percentage of the various size of soil grains percent in a given dry soil sample is carried out by mechanical sieve analysis for coarse grain and whereas fine-grained soils are analysed by the hydrometer method. Graphs are shown in Appendix G.

Specific gravity results determined in Table (2) for the soil samples by using a pycnometer.

Samples No. (m)	Specific Gravity
SPILE	2.74
PCL	2.74

Table No.(2) Specific Gravity Test Results

Single Oedometer Collapse Test carried out for samples in four stages with different moisture content. **First**, by using 8% moisture content which is less than the optimum moisture content, and loaded in the conventional oedometer to a stress level 200kpa and then inundation by distilled water is applied to induce collapse. Two rings for test are taken, one at a Top of the mould other in the Bottom for samples SPILE and PCL separately. (disturbed sample compacted with 8% moisture content at the mould in three layers, then two consolidation rings pushed entire the samples, one at top side and other in bottom side).

Second by using 13% of moisture content which is more than the optimum moisture content for two rings at top and bottom. Graphs and results are shown in appendix G.

The sample results which used 8% moisture content shows that, the difference between void ratio from saturation values Δe_c is high compared to that of moisture content 13%.

Table (3) shows the results of single oedometer test and results of collapse potential.

Sample	Case	e_o	e_1	e_2	C_p
SPILE	8% moisture content (TOP)	0.36817	0.33279	0.25166	5.90%
SPILE	8% moisture content (BOTTOM)	0.37301	0.27274	0.23016	3.12%
SPILE	13% moisture content (TOP)	0.30847	0.27689	0.27596	0.071%
SPILE	13% moisture content (BOTTOM)	0.25847	0.23317	0.23228	0.071%
PCL	8% moisture content (TOP)	0.62009	0.49638	0.43158	4.0%
PCL	8% moisture content (BOTTOM)	0.54476	0.50044	0.39621	6.74%
PCL	13% moisture content (TOP)	0.34157	0.30146	0.29861	0.212%
PCL	13% moisture content (BOTTOM)	0.31702	0.27339	0.27060	0.212%

Table(3) Single oedometer and Collapse potential Results

Double Oedometer Collapse Test is carried out by two identical samples are placed in oedometers; one tested at in-situ natural moisture content, and the other is fully saturated before the test begins, and then subjected to identical loading. These were taken for samples SPILE and PCL,

Two, stress versus strain curves are generated. The difference between the compression curves is the amount of deformation that would occur at any stress level at which the soil get saturated. Results for double oedometer collapse test are shown in Appendix G indicated low void ratio at the difference between natural moisture and added water to sample in collapse soil for samples SPILE and PCL. Also, at same initial void ratio of natural moisture content and water added curves at appendix G and Tables (4-1) and (4-2), the collapse potential C_p indicated medium to high collapse.

P KN/m ²	e_1	e_2	e_o	C_p (%)
80	0.421	0.459	0.501	2.532
160	0.392	0.438	0.501	3.051
320	0.361	0.420	0.501	3.924
640	0.318	0.392	0.501	4.930

Table (4-1) Double collapse Results of C_p for PCL sample


P KN/m²	e₁	e₂	e_o	C_p(%)
160	0.3460	0.3530	0.3658	0.5125
320	0.3200	0.3390	0.3658	1.3911
640	0.2830	0.3200	0.3658	2.7090

Table (4-2) Double collapse Results of C_p for SPILE sample




APPENDIX (G)
RESULTS FOR TESTS OF SAMPLES
SPILE AND PCL


Grain Size Distribution Curve
Kosti Thermal Power Station
Sample No. SPile



Grain Size Distribution Curve
Kosti Thermal Power Station
Sample No. PCL




**Hydrometer Curve
 Kosti Thermal Power Station
 Sample No. SPILE**




Clay	Silt	Sand	Gravel
------	------	------	--------


KOSTI THERMAL POWER STATION PROJECT
 S/Tile / Top
 8% Moisture Content
 SOIL COLLAPSE USING SINGLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
 Spile / Bottom
 8% of Optimum Moisture Content
 SOIL COLLAPSE USING SINGLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
 SPile / Top
 13% Moisture Content
 SOIL COLLAPSE USING SINGLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
 SPile / Bottom
 13% Moisture Content
 SOIL COLLAPSE USING SINGLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
 PCL / Top
 8% Moisture Content
 SOIL COLLAPSE USING SINGLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
PCL / Bottom
8% Moisture Content
SOIL COLLAPSE USING SINGLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
 PCL /Top
 13% Moisture Content
 SOIL COLLAPSE USING SINGLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
 PCL / Bottom
 13% Moisture Content
 SOIL COLLAPSE USING SINGLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
 Sample: PCL
 SOIL COLLAPSE USING DOUBLE OEDOMETER




KOSTI THERMAL POWER STATION PROJECT
Sample: SPile
SOIL COLLAPSE USING DOUBLE OEDOMETER





KOSTI THERMAL POWER STATION PROJECT
Sample: SPIle
SOIL COLLAPSE USING DOUBLE OEDOMETER
Same Initial Void Ratio




KOSTI THERMAL POWER STATION PROJECT
Sample: PCL
SOIL COLLAPSE USING DOUBLE OEDOMETER
Same Initial Void Ratio






MCC ROOM - CW PUMP HOUSE



PLAN AT EL.(±)0.00M.



ELEVATION ALONG GRID 1

MCC ROOM-RIVER SIDE INTAKE PUMP HOUSE





TABLE-C (INTAKE PUMP HOUSE FENCING AREA)

NO	EASTING	NORthing	ELEVATION
F1	474667.246	1451927.596	RL+383.0
F2	474882.902	1452039.405	RL+383.0
F3	474507.121	1451982.233	RL+383.0
F4	474591.375	1451870.424	RL+383.0

TABLE-C (INTAKE PUMP HOUSE PLOT AREA)

NO	EASTING	NORthing	ELEVATION
D1	474723.727	1451929.695	RL+383.0
D2	474804.010	1451839.509	RL+383.0
D3	474363.330	1452158.998	RL+383.0
D4	474483.047	1452249.184	RL+383.0

FOUNDATION RESTING ON VIRGIN SOIL

- REFERENCE DRGS.:-
1. KOSTI POWER PLANT CONTOUR
 2. RIVER SITE CONTOUR
 3. KOSTI POWER PLANT PROJECT (LOCATION OF POWER STATION & NILE RIVER)
 4. L.O.D PLAN
 5. P&ID PLANT WATER SYSTEM
 6. G.A. OF RAW WATER INTAKE PUMP HOUSE
 7. RAW WATER INTAKE PUMP

NOTES
1. RAW WATER INTAKE PUMP HOUSE FINISHED FLOOR LEVEL IS EL.(F.D)0M WHICH CORRESPONDS TO RL 383.50M.

KOSTI Thermal Power Station 4x125 MW

NATIONAL ELECTRICITY CORPORATION (NEC)
THE REPUBLIC OF THE SUDAN

FICHTNER
Fichtner GmbH & Co. KG
Stuttgart, Germany

BHARAT HEAVY ELECTRICALS LTD
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NEW DELHI

DEPT. SGNL NAME SIGN DATE



DESN	RAJ HUSSAIN		18.11.08
CHKD	RAJ HUSSAIN		18.11.08
APPR	SUNIL		18.11.08

TITLE: PLOT PLAN LOCAL TO INTAKE PUMP HOUSE AREA


DEPT.	SCALE	DRAWING NO.
SGNL		PE-250-DG-100-MSK25A
DATE		SHEET 1 OF 1
		REV. 0

**Settlement in MCC Room in River Water Intake Pump House -
Ground floor including cable trenches**






SECTION 2-2



PLAN



VIEW 3-3-CAT-1
APPROVED

Checked and approved with regard to the system requirements and/or main dimensions and/or the overall arrangement. The Contractor is responsible for design calculation, detail dimensions and operability.

FICHTNER

Signature: _____ Date: _____

NOTES:-

1. ALL DIMENSIONS ARE IN MILLIMETRE.
2. DO NOT SCALE THE DRAWING, FOLLOW WRITTEN DIMENSIONS ONLY.
3. GRADE OF RCC SHALL BE M25.
4. ALL REINFORCEMENT (DENOTED AS ϕ) SHALL CONFIRM TO IS:1786-1985 OF GRADE Fe415.
5. CLEAR COVER TO MAIN REINFORCEMENT SHALL BE AS FOLLOWS:-

ITEMS	TOP	BOTTOM	SIDE
a) RAFT	50	50	50
b) COLUMN	50	-	50
6. FOR FOUNDATION LAYOUT PLAN REFER DWG. NO. TB-1-279-607-604
7. FOR DETAILS OF TOWER FOUNDATION BOLTS REF. DWG. NO. TB-3-279-607-602-2

REV.	DATE	DESCRIPTION	PREPARED	CHECKED	REVIEWED	APPROVED
A	14.12.09	REVISED AS PER FCE COMMENTS	JUGENDRA	AA	BVG	RMS
00	29.10.09	FIRST SUBMISSION	JUGENDRA	AA	BVG	RMS

KOSTI, Thermal Power Station 4 x 125 MW

NATIONAL ELECTRICITY CORPORATION (NEC)
THE REPUBLIC OF THE SUDAN

FICHTNER Fichtner GmbH & Co. KG
Stuttgart, Germany

Bharat Heavy Electrical Ltd., Delhi, India

Subcontractor

DRWG. NO: **TB-3-279-607-608-7-A**

CHIEF, ENG.	PROJECT ENG.	
DESIGN MANAGER	CHECK	
DEPT. CHIEF	DESIGN ENG.	
SECTION CHIEF	SCALE	
CAD-FILE	DATE:	

DRWG. NO: **KTPS-AD-00-DW-608-7-A**

DRAWING TITLE: RCC DETAILS OF EQUIPMENT FOUNDATION FOR 220KV PI (MIDDLE LEVEL) MKD. F6A

INVENTORY No. _____
 DATE _____
 REF. DRG. No. _____
 DRAWING No. TB-3-279-607-608-7-A