



**Power Sector – PEM Noida
Technical Pre - Qualification
Requirements
(For Open/Global Tender)**

Package: ELECTRIC HOIST

**DEPARTMENT: Mechanical Auxiliary
Engineering**

Sheet 1 of 2

REV 00

Pre-Qualification Requirements:- ELECTRIC HOIST – Minimum 3T capacity

- 1) Electric Hoists should have been successfully in use for at least one year in power plant or other industries e.g. refinery/steel/process/commercial etc. For this the supplier has to submit either of following supporting documents meeting above mentioned pre-qualifying requirement:
 - i) Copy of minimum two performance certificate from end user along with copy of related Purchase Order specifying that the product is running successfully for one (1) year from date of commissioning.

OR
 - ii) Minimum three customer's/third party inspection reports along with purchase order copy meeting the minimum pre-qualifying requirement

OR
 - iii) Minimum three purchase orders (placed with minimum gap of 6 months from previous purchase order) from same purchaser meeting the minimum pre-qualifying requirement
- 2) Vendor should have designing/manufacturing capability and having testing facility (in house or outsourced).
- 3) To establish above, supplier shall submit the following for BHEL verification:-
 - a) Vendor shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
 - b) Minimum two (2) nos. Purchase orders shall be submitted which should not be more than ten (10) years old as on date of bid submission, for establishing continuity in business. Supplier's Experience List of offered system on the enclosed format Annexure A.
 - c) Vendor may also qualify based on the credential of principal meeting package specific pre-qualifying requirements having technical valid collaboration/licensing agreement.
 - d) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.
 - e) PEM registered vendors without technical limit are not required to submit the credentials to meet the PQR in case of open/global tender, however credentials may be required to be submitted for customer approval.
 - f) PEM registered vendors with technical limit are required to check PQR in case of open/global tender and will submit the credentials, if project specific PQR is more stringent than technical limit of registration in PEM. In such case, the bidder will be evaluated based on credentials.



**Power Sector – PEM Noida
Technical Pre - Qualification
Requirements
(For Open/Global Tender)**

Package: ELECTRIC HOIST

DEPARTMENT: **Mechanical Auxiliary
Engineering**

Sheet 2 of 2

REV 00

Experience Detail Format (Annexure A)

Sl.No.	Description of Project	Brief Scope of work	P.O. Ref. No. & Date	Purchase order value (Rs).	Date of completion as per P.O.	Performance Certificate enclosed (Y/N)	Remark