

BHEL replies to pre - bid queries for NIT_18498 (Enquiry No. T7J1N80918)**Project: RUPPL, HMD**

SI No	Bidder's queries / interpretation	BHEL Reply
1	Scope of supply of Piping & exclusion of Scope shall be as per clause no.1.1 & 1.2 of specification PY52043;	It is in order
2	ISOMETRIC Drawings comprising BOQ in AUTOCAD FORMAT shall also be Provided by M/s BHEL.so that Spool marking & other fabrication detail could be incorporated in the drawings and shall forwarded for BHEL APPROVAL.	It is in order
3	there is no IBR approvals involved in this scope	Yes
4	Size & length of Spools shall be transport worthy as against the maximum transportable length mentioned as 6 M (L) in the event of transport arrangement by trailers.	It is in order
5	With regards to the shoe pads for supports, we presume ththe same to be send as loose pieces in accordance with clause no; 1.3 (e).	No loose pieces; shoe pads to be Welded to pipes.
6	Shoe Pads are to be welded from 2" & above	Yes (Refer cause no: 1.3 of specification PY52043)
7	Can we go ahead with fabrication based on Isometric Drawings? Or need to make fabrication drawings	vendor to submit spool drawings, before start of fabrication
8	Weather Proof wooden box packing required for Spools of 6 meters also?	yes; all supplies to be made in weather proof wooden boxes s per Clause 7.3 of SPEC PY52043
9	Is Price to be quoted inclusive of transportation?	Bidder to refer to clause 5.A, 5.B of annexure-BB Clause remains same.