

Technical Specification for Enquiry No. E-7130556

1. DISCRIPTION:

HEAT SHRINK END TERMINAL KIT SUITABLE FOR 1 CORE 500 SQ MM. ALUMINIUM CONDUCTOR XLPE INSULATED INDOOR 11 KV GRADE ARMoured CABLE.

- A. **QTY.**:- 30 nos.
- B. **Delivery Required in Jan-14**
- c. Erection & Commissioning is not required.
- d. CEBG/EMD is not required for above item