



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 4X270 MW BHADRADRI TPS
PACKAGE : MISC. PUMPS (HORIZONTAL)

DATE: - 04.09.2015

Reference: PE/PG/MG1/ E-5021/15/CORRIGENDUM/02

ENQUIRY NO.: E-5021/15 **Dated. 24.08.2015**
PE/PG/MG1/ E-5021/15/CORRIGENDUM/01

Subject: Clarification and addenda to delivery schedule.

1. The below mentioned details are further clarification to the delivery schedule & must be read in conjunction Delivery Schedule of NIT.

The drawings to be submitted by bidder in the event of order for subject project shall be:

PACKAGE	BHEL DRG NO	DRG TITLE	DRG SCH FOR VENDORS	REMARKS
MISC. PUMPS (HORIZ.)	PRIMARY DOCUMENTS - AFFECTING MANUFACTURING/ DELIVERY DIRECTLY			
	PE-V6-411-100-N001	TDS AND PERFORMACE CURVES- MISC. PUMPS	R-0 WITHIN 10 DAYS FROM PO & SUBSEQUENT REVISIONS WITHIN 5 DAYS OF COMMENTS RECEIVED FROM BHEL.	PUMP CROSS SECTION DRAWING IN CASE OF HT MOTOR DRIVEN PUMP, PRELIMINARY(R-0) WITHIN 10 DAYS FROM PO & FINAL A/W PUMP GA WITHIN 5 DAYS OF RECEIPT OF MOTOR GA FROM BHEL.
	PE-V6-411-100-N002	GENERAL ARRANGEMENT AND CROSS SECTIONAL-PUMPS		
	PE-V6-411-100-N003	TDS AND CURVES OF MOTORS FOR MISC. PUMPS		
	PE-V6-411-100-N004	QP-MISC PUMPS		
	SECONDARY DOCUMENTS - NOT AFFECTING MANUFACTURING/ DELIVERY DIRECTLY			
	PE-V6-411-100-N005	QP- MOTORS	R-0 WITHIN 10 DAYS FROM PO & SUBSEQUENT REVISIONS WITHIN 5 DAYS OF COMMENTS RECEIVED FROM BHEL.	
	PE-V6-411-100-N006	MOTOR TYPE TEST DOC (IF APPLICABLE)		
	PE-V6-411-100-N007	O& M MANUAL -HOR. PUMPS	WITHIN 10 DAYS FROM MDCC	

For pumps where HT motor is to be free issued by BHEL, HT motor GA will only affect the GA drawing preparation from vendor. Vendor to furnish tentative GA drawing for pump within specified time schedule. Vendor to furnish final GA drawing within 5 days of receipt of Motor GA drawing from BHEL. Bidders to note that HT motors inputs viz. Load Torque vs. speed curves of the pumps, selected motor ratings, rpm, GD2 value of driven equipment furnished along with offer shall be considered final and BHEL may proceed with final motor designs as per same.

Regards

Anil Kumar Pal
Sr. Manager
PG-II
0120-4368597
BHEL PEM Noida