

ANNEXURE I – LIST OF PRE-BID QUERIES

Sr No	CLAUSE	DESCRIPTION	QUERIES	BHEL's COMMENTS
1.	Tender doc: PE-TS-411-163A-A001, Vol: IIB, Annexure III, Sheet 6 of 12	4.3 Cation exchanger resin 4.4 Anion exchanger resin 4.5 Mixed Bed resin	To achieve the guarantee parameters is not necessary to provide the Uniform particle Size (UPS) resin. We suggest Non-UPS resin to achieve the guarantee parameters Kindly confirm the same.	Bidder to follow tender specification requirement.