

PRE-QUALIFICATION CRITERIA

JOB	DESIGN, ENGINEERING, MANUFACTURING, SUPPLY/ DELIVERY TO SITE OF CONTROL VALVES (Pneumatically Operated) WITH SMART POSITIONER & ACCESSORIES FOR 2 x 660 MW SURATGARH STPS STAGE V.
------------	--

BIDDER SHALL NOTE & COMPLY WITH THE POINTS REFERRED BELOW.

SR. NO.	CRITERIA FOR BIDDERS NOT APPROVED WITH BHEL-PEM, NOIDA:
1.0	BIDDER SHOULD BE DESIGNER & ORIGINAL EQUIPMENT MANUFACTURER OF THE CONTROL VALVE WITH ACCESSORIES.
2.0	BIDDER TO FURNISH LIST OF ORDERS EXECUTED IN LAST FIVE YEARS.
3.0	<p>a. SATISFACTORY PERFORMANCE FEEDBACK CERTIFICATES FROM END USER (IN ENGLISH) FOR THERMAL POWER PLANT APPLICATION, INDICATING SALIENT FEATURES LIKE YEAR OF COMMISSIONING OF EQUIPMENT, DUTY PARAMETERS (SIZE ,FLOW), PROJECT NAME ETC., DATE OF ISSUE OF CERTIFICATE AND NAME/DESIGNATION OF THE CERTIFICATE ISSUER.</p> <p style="text-align: center;">OR</p> <p>THE SUPPLIER HAS BEEN AWARDED REPEAT CONTRACTS (MINIMUM 2 NOS.) BY SAME CUSTOMER FOR CONTROL VALVE AFTER 2 YEARS OF COMMISSIONING OR ON REGULAR BASIS FOR THERMAL POWER PLANT RATING 500 MW & ABOVE.</p> <p>b. TWO SETS OF APPROVED DRGS, TECHNICAL DATA SHEETS OF WHICH THE BIDDER INTENDS TO FURNISH THE PERFORMANCE FEEDBACKS, FOR REFERENCE PURPOSE.</p>
4.0	MANUFACTURER SHOULD COMPLY WITH BHEL/CUSTOMER APPROVED QUALITY PLAN & SPECIFICATION FOR CONTROL VALVES.(As per Annexure attached) A CONFIRMATION FOR THE SAME SHALL BE SUBMITTED.
5.0	<p>BIDDER SHALL HAVE THE CAPABILITY/REFERENCE OF SUPPLYING CONTROL VALVES</p> <ol style="list-style-type: none">1. ATLEAST THE VALVE SIZE OF 14 INCH & ANSI RATING 3000 SPL CLASS.2. SHUT OFF PRESSURES UPTO 470KG/CM23. DESIGN TEMPERATURES UPTO 370 DEG C4. DIFFERENTIAL PRESSURES UPTO 90 KG/CM2 <p><i>RELEVANT DOCUMENT IN SUPPORT OF ABOVE SHALL BE SUBMITTED</i></p>
6.0	BIDDER TO FURNISH TECHNICAL CATALOGUE OF CONTROL VALVES.

NOTES

1.0 BIDDER(S) ALREADY REGISTERED WITH BHEL-PEM-NOIDA FOR SUBJECT PACKAGE, WITHOUT ANY TECHNICAL LIMIT, NEED NOT SUBMIT TECHNICAL PQC/PQR. IN CASE OF LIMIT, THE REGISTERED BIDDER TO SUBMIT THE DOCUMENTS REQUIRED FOR REVIEW OF LIMIT ALONE, IF THE BIDDER WANTS RE-ASSESSMENT OF THE LIMIT.

2.0 AFTER SATISFACTORY FULFILLMENT OF ALL THE ABOVE CRITERIA/ REQUIREMENT, OFFER SHALL BE CONSIDERED FOR FURTHER EVALUATION AS PER NIT AND ALL OTHER TERMS OF THE TENDER.

3.0 CONSIDERATION OF OFFER WILL BE SUBJECT TO END USER'S APPROVAL OF BIDDER.