

TECHNICAL PRE-QUALIFICATION CRITERIA

JOB	DESIGN, ENGINEERING, MANUFACTURING, SUPPLY/ DELIVERY TO SITE OF CONTROL VALVES (Pneumatically Operated) WITH SMART POSITIONER & ACCESSORIES FOR 2 x 800MW GADARWARA STPP STAGE-I.
-----	---

BIDDER SHALL NOTE & COMPLY WITH THE POINTS REFERRED BELOW.

SL NO	CRITERIA FOR BIDDERS NOT APPROVED WITH BHEL-PEM, NOIDA:
1.0	BIDDER SHOULD BE DESIGNER & DIRECT MANUFACTURER OF THE CONTROL VALVES WITH ACCESSORIES
2.0	BIDDER TO FURNISH EXPERIENCE CERTIFICATES FOR MIN. 2 YEARS OF TROUBLE FREE OPERATION FROM MINIMUM 2 DIFFERENT END USERS, PREFERABLY FROM POWER PLANT OF RATING 600MW & ABOVE.
3.0	MANUFACTURER SHOULD COMPLY WITH BHEL QUALITY PLAN & SPECIFICATION FOR CONTROL VALVES. A CONFIRMATION FOR THE SAME SHALL BE SUBMITTED.
4.0	BIDDER TO FURNISH EXPERIENCE LIST/ ORDER EXECUTED IN LAST FIVE YEARS.
5.0	BIDDER SHALL HAVE THE CAPABILITY/REFERENCE OF SUPPLYING CONTROL VALVES WITH <ol style="list-style-type: none">1. ANSI RATING UPTO CLASS-6002. VALVE SIZE UPTO 14 INCH3. SHUT OFF PRESSURES UPTO 90 KG/CM24. DESIGN TEMPERATURES UPTO 370 DEG C5. DIFFERENTIAL PRESSURES UPTO 85 KG/CM2 <i>RELEVANT DOCUMENT IN SUPPORT OF ABOVE SHALL BE SUBMITTED</i>
6.0	BIDDER TO FURNISH TECHNICAL CATALOGUE OF CONTROL VALVES.

NOTES

1.0	BIDDER(S) ALREADY REGISTERED WITH BHEL-PEM-NOIDA FOR SUBJECT PACKAGE, NEED NOT SUBMIT CREDENTIALS FOR CRITERIA INDICATED ABOVE.
2.0	AFTER SATISFACTORY FULFILLMENT OF ALL THE ABOVE CRITERIA/ REQUIREMENT, OFFER SHALL BE CONSIDERED FOR FURTHER EVALUATION AS PER NIT AND ALL OTHER TERMS OF THE TENDER.
3.0	CONSIDERATION OF OFFER WILL BE SUBJECT TO END USER'S APPROVAL OF BIDDER.

#