

## **Changes in specifications of 2750 kva input transformer.**

**Enquiry no. 330701141 due on 19-06-2007**

**NIT no. 2895**

SI no 14. Impedance / Tolerance : 12% on principal tap ( Minimum)  
Tolerance + 10 % - 0 %

SI no 15. Impedance / Coupling : Impedance / tolerance as specified in pt 14  
(i) 12% impedance with tolerance between HV and LV-1 on 1375 KVA base with LV-2 open.  
(ii) 12% impedance with tolerance between HV and LV-2 on 1375 KVA base with LV-1 open  
iii) The two LV windings should have minimum mutual leakage coupling inductance.

**Revised Tender opening date : 21-07-2007**