



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 1X800 MW KOTHAGUDAM STPP
PACKAGE : COOLING TOWER.
ENQUIRY NO : E-4750/2014 Dtd 27.03.2015

DATE: - 12.08.2015

Sl. No.	Bidder's query	BHEL Clarification
1.	<p>Sl. # 5 - Replies to Bidder's queries</p> <p>Our understanding is that conducting drift loss test at site is applicable only when the cooling tower is designed without drift eliminators. Since we are designing our cooling tower with drift eliminators, demonstration of drift loss should not be applicable. Please confirm.</p> <p>We would like to mention here that this has already been confirmed / accepted by BHEL PEM in all their previous tenders including the latest tender for NDCT for 1 x 800 MW Wanakbori TPP (Enquiry No: PE/PG/WAN/E-4865115 dated 02-06-2015).</p>	<p>Specification to be complied.</p> <p>PG Test procedure shall be subject to customer approval during detailed engineering.</p>