

BHEL PEM-ELECTRICAL

**PRE-QUALIFYING REQUIREMENTS FOR LT EPR FIRE SURVIVAL CABLES
DOC. NO. PE-PQ-999-507-E018, REV. 1**

ITEMS : LT EPR fire survival cables

SCOPE:

Supply : YES; Erection & Commissioning : NO;

A) GENERAL CRITERIA FOR EVALUATION

1. Vendor should be a manufacturer of LT EPR fire survival cables with copper conductor.
2. In-house capability to carry out all routine, type & acceptance tests (including fire survival test) as per relevant IS/International standards on LT EPR fire survival cables. In case facilities for fire survival test are not available with the vendor, these tests can be conducted at Govt. Lab/ Govt. approved independent Lab.
3. Capacity of manufacturing 200 km of power/control cables (including non-EPR cables) per month.
4. Availability of type test certificates conducted at independent Lab or witnessed by third party as per relevant IS/International standards.
5. Manufactured & supplied at least 10 km of LT EPR fire survival cables in single or in combination of two orders in last 5 years.
- 6a. Experience certificates for minimum 2 years of trouble free operation from minimum 2 different end users for LT EPR fire survival cables.
OR
- 6b. Repeat order received from 2 different end users for LT EPR fire survival cables during last 5 years provided the gap between award of two PO's is minimum 3 years.
OR
- 6c. 1 no. experience certificate (as per sl. no. 6a) and 1 no. repeat order (as per sl. no. 6b).
OR
- 6d. Successful execution of a major order (i.e. supply of minimum 5 km of LT EPR fire survival cables in single order) for NTPC EOC, Noida/ EIL/ NPCIL.

Note :

Vendor(s) should submit relevant documents in support of above mentioned General Criteria.

Vishish Shukla
24/7/15

Adarsh
24/7/15

Fajal
24/7/15

M/2015
24.7.15

BHEL PEM-ELECTRICAL

**PRE-QUALIFYING REQUIREMENTS FOR LT EPR FIRE SURVIVAL CABLES
DOC. NO. PE-PQ-999-507-E018, REV. 1**

B) PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY

1. After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.
2. Consideration of offer will be subject to customer's approval of bidder (if applicable).
3. Any other project specific requirement shall be as per Annexure-I and bidder shall submit relevant supporting documents.

Manish Shukla
24/7/15
Manish Shukla
[Technical Convenor]

SK Gurumukhi
24/7/15
SK Gurumukhi
[SH-E02]

Rajnish Goyal
24/7/15
Rajnish Goyal
[SH-E03]

Praveen Dutta
24/7/15
Praveen Dutta
[SH-E01]

Meena Kesri
24.7.15
Meena Kesri
[DH-Electrical]

BHEL PEM-ELECTRICAL


PRE-QUALIFYING REQUIREMENTS FOR LT EPR FIRE SURVIVAL CABLES
DOC. NO. PE-PQ-999-507-E018, REV. 1

ANNEXURE - I


PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY

PROJECT: 1x800 MW KOTHAGUDEM POWER PROJECT

- NIL -


[Dealing Engineer]

[Controlling Officer]


[Section Head]


[DH-Electrical]