

SS

Amendment in Technical Specification of PVC Fills

Dt.: 20.07.15

Ref. NIT No.: 7580/S/6160/15/1585A1

With reference to the above mentioned NIT no., there is an amendment in the technical specification of the PVC fills which is as follows:

- The PVC fills is required for 225TR water cooling tower of size: 600mm X 300mm X 150mm with flute size of 12mm and corresponding model: C-10-12.

Ashish  
20/07/15

Ashish Maithani  
Sr. Engineer (WEX-AC)

1  
Kataria  
20/07/15  
(A.K. Kataria)  
SDGM (WEX-AC)