

DM PLANT - 4 x 270 MW BHADRADRI THERMAL POWER PROJECT
SCHEDULE OF PRE-BID CLARIFICATION

All clarification from the Technical Specification shall be filled in by the BIDDER clause by clause in this format only.

VOLUME	SECTION	CLAUSE NO.	PAGE NO.	SPECIFICATION REQUIREMENT	CLARIFICATION	REASONS FOR CLARIFICATION	BHEL REPLY
COMMERCIAL QUERIES:							
GENERAL	-	-	-	-	Kindly confirm whether separate orders are issued for Supply & Service Part.	For bidder's confirmation	Separate LOI's shall be issued for Main Supply, E & C and Supply of Mandatory Spares.
GENERAL	-	-	-	-	Kindly confirm whether Road permits & Way bills for materials purchased outside Telangana shall be provided by BHEL.	For bidder's confirmation	Road permit is applicable & shall be provided by BHEL for materials purchased outside Telangana.
GENERAL	-	-	-	-	Whether Service Tax applicable on Services part would be paid extra . Also kindly inform where the Service tax amount on Service Part to be indicated in the Price Bid Format.	For bidder's confirmation	Refer clause no-18.A (i.e. Taxes & Duties) of SCC Rev-01 of the project.
GENERAL	-	-	-	-	Form C shall be issued by BHEL on Quarterly basis before the end of subsequent Quarter.	For bidder's confirmation	Refer clause no-4.2.4 of GCC Rev-06.
GENERAL	-	-	-	-	Kindly provide us BHEL VAT registration number for Telangana.	For bidder's confirmation	
GENERAL	-	-	-	-	For Imports purchases kindly let us know whether BHEL would sign High Sea Sales agreement and also to provide applicable certificate , import & Export registration codes.	For bidder's confirmation	It shall be provided later.
GENERAL	-	-	-	-	Kindly confirm Insurance coverage during transit, storage, erection & commissioning is under the scope of BHEL and hence Insurance premium costs would not be in the Scope of Contractor.	For bidder's confirmation	Refer clause no-17 of GCC Rev-06.
GENERAL	-	-	-	-	Any concessions / Benefits / Exemptions on Taxes & Duties would be available for this job.	For bidder's confirmation	Refer clause no-18.A (i.e. Taxes & Duties) of SCC Rev-01 of the project.
GENERAL	-	-	-	-	If single order is issued for the Price Schedule, BHEL shall countersign in the Purchase Order.	For bidder's confirmation	Separate LOI's shall be issued for Main Supply, E & C and Supply of Mandatory Spares.
GENERAL	-	-	-	-	Kindly inform us whether Service Tax (Reverse Charge) applicable on freight would be reimbursed or it should be loaded in the Price Bid.	For bidder's confirmation	Freight to be quoted inclusive of service tax (refer coloumn no-6 of main price schedule). Freight shall be considered in evaluation (refer SCC Rev-01)
GENERAL	-	-	-	-	If two separate orders are issued for Supply & Services, TDS under telangana VAT would not be applicable. For supply part Tax invoice would be submitted and for Service Part , Service Tax invoice would be submitted. Hence Running Bills would not be submitted.	For bidder's confirmation	Refer NIT & GCC Rev-06
GENERAL	-	-	-	-	Please confirm VAT registration under Telangana would not be required for the Contractor since Supply invoice would be submitted using Tamil Nadu VAT / CST registration since all the materials would be purchased outside the state of telangana	For bidder's confirmation	Refer NIT & GCC Rev-06
GENERAL	-	-	-	-	Whether the Billing Schedule of the order be jointly signed by Owner and Contractor for the contract price.	For bidder's confirmation	As per NIT
GENERAL	-	-	-	-	Please confirm all Civil works is not envisaged in this contract.	For bidder's confirmation	Bidder to follow the tender specification.
PROCESS QUERIES:							
Technical Specification for DM Plant	(X)	ANNEXURE- IX - INPUT DRAWING	246 OF 468	PLOT PLAN	Please confirm the distance from the pump house in the clarified water storage tank to DM plant. To fix the head of the vertical sump pump.	For bidder's confirmation	Bidder to refer the tender specification in conjunction with Annexure -9 of drawings, plot plan (page 246 of 468).
Technical Specification for DM Plant	(X)	ANNEXURE- IX - INPUT DRAWING	246 OF 468	PLOT PLAN	Please confirm whether pipe rack or pedestal shall be provided by BHEL for the piping from Pump house in the clarified water storage tank to DM plant.	For bidder's confirmation	Bidder to follow the tender specification.
Technical Specification for DM Plant	(X)	ANNEXURE- IX - INPUT DRAWING	243 OF 468	PROCESS & INSTRUMENT DIAGRAM FOR DEMINERALISATION PLANT	Please confirm whether DM regeneration is automatic or manual. Since the valves in the PROCESS & INSTRUMENT DIAGRAM FOR DEMINERALISATION PLANT contains only manual.	For bidder's confirmation	Bidder to refer note number 1 of P&ID of DM plant "The P&ID enclosed in indicative and with minimum requirements only". Any changes/additional item required to provide semi automatic operation of the DM plant as elaborated in the volume-10, Section D1, clause number 2.0, page 252 of 468 of the specification shall be considered by the bidder in his scope to meet the system and contract requirement.
General	-	-	-	-	Please confirm whether chemical guarantee is also there in the bid evaluation.	For bidder's confirmation	Bidder to note that guaranteed Chemical consumption furnished by the bidder shall not be considered under bid evaluation.
Technical Specification for DM Plant	C1 - F - Datasheet	30, valves	169 OF 468	Note: All valves shall be double flanged type. The type of valves shall be as per the type shown in P&ID only	Please confirm whether the all the valves shown in DM plant are double flanged type.	For bidder's confirmation	Bidder to follow the tender specification.
ELECTRICAL & INSTRUMENTATION QUERIES:							
Technical Specification for DM Plant		10	Pg 17/468	Exclusions: 10.4 Air conditioning, ventilation & fire fighting facilities.			Bidder to note that air conditioning, ventilation & fire fighting facilities for DM plant package shall not be in bidder's scope.
Technical Specification for DM Plant	Annexure II	D) Control Room	Pg 53/468	Necessary Air Conditioning shall be provided for Central Control room, Control Equipment Room and SWAS room etc.	As both the statements are contradictory, kindly confirm whether the Bidder should consider A/C for the Control Room	Both the statements are contradictory	
Technical Specification for DM Plant	Annexure II	D) Control Room	Pg 53/468	The Control Room lighting shall be designed to provide a glare free uniform illumination. The level of illumination shall be minimum 400 LUX.	Kindly confirm whether the Bidder should provide lighting in the Control Room	For bidder's confirmation	Bidder to refer & follow ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR of the tender specification (page 179 of 468) .
Technical Specification for DM Plant	ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR		Pg 179/468		The bidder has understood that the following cables does not come under the scope of Bidder 1) Cables between MCC and PLC Kindly confirm	For bidder's confirmation	Bidder to follow the tender specification.