

**SEWAGE TREATMENT PLANT - 4 x 270 MW BHADRADRI THERMAL POWER PROJECT  
SCHEDULE OF PRE-BID CLARIFICATION**

All clarification from the Technical Specification shall be filled in by the BIDDER clause by clause in this format only.

VOLUME	SECTION	CLAUSE NO.	PAGE NO.	SPECIFICATION REQUIREMENT	CLARIFICATION	REASONS FOR CLARIFICATION	BHEL Reply
<b>COMMERCIAL QUERIES:</b>							
GENERAL	-	-	-	-	Kindly provide us BHEL VAT registration number for Telangana.	For bidder's confirmation	It shall be provided before placement of PO/LOI.
GENERAL	-	-	-	-	For Imports purchases kindly let us know whether BHEL would sign High Sea Sales agreement and also to provide applicable certificate , Import & Export registration codes.	For bidder's confirmation	Not Applicable
<b>PROCESS QUERIES:</b>							
6a. Indian Bidder- Price Schedule-STP-BHADRADRI	PRICE SCHEDULE FOR SEWAGE TREATMENT PLANT	3.0	1	Break-up (%) of prices given at SI No-2.1 above (To be used during contract execution for payment).	Please confirm whether we can give the percentage breakup according to our estimated cost.Since most of the percentage are not matching to our estimation.	For bidder's confirmation	Bidder to follow BHEL price schedule only.
Technical Specification for Sewage Traetment Plant	C1-F/Data sheet A	12.1	150 OF 431	Sewage transfer piping - MOC - CI	Please confirm us whether we can go for any other material of construction for sewage transfer piping.	Since the minimum size available in CI is 80 NB. But the our flow rate is 3m3/hr which leads to velocity in the discharge pipe is 0.1 m/s which is very low in pump discharge piping.	Bidder to follow tender specification.
Technical Specification for Sewage Traetment Plant					Instrumentation Cable (Ref.CABLE BOQ-Page no. 418 /431 of Tech. Specification PE-TS-411-673A-A001) - Supplies are under whose scope.	For bidder's confirmation	Bidder to refer electrical scope page no. 159 to 162 of 431 for cable supply scope included in tender specification
Technical Specification for Sewage Traetment Plant					Sewage Sump Pipes (Page no. 12/431 of Tech. Specification PE-TS-411-673A-A001) - Diameters of the Pipes have not been mentioned, required to be specified for the purpose of costing.	For bidder's confirmation	Bidder to decide pipe diameter as per process and specification requirement at their end.
Price Schedule for Sewage Traetment Plant					Price Schedule - SI. No. 3 - Items are not mentioned. So, unable to determine the basis of Price.	For bidder's confirmation	Bidder to refer agitator indicated in NaOCI tank included in P & ID of sewage treatment plant of tender specification. .