

SUPPLY & INSTALLATION OF 1.5 TON PRECISION SPLIT A.C UNITS WITH MICRO PROCESSOR CONTROLLER				PR Nos: 6000001511
Sl.	Specifications / Description for BHEL Requirement		Deviations	Remarks
1.5 TR capacity Precision Split Air Conditioner FIVE STAR RATING, technical specifications				
1	Tenderer should be Own Equipment Manufacturer (OEM)/Authorized Dealer of OEM (Authorization Certificate to be enclosed).	Vendor to indicate		
2	1.5 ton 5 Star Rated precision Split AC with Micro Processor controller make and model no	Vendor to confirm and indicate		
3	Rated Cooling capacity /Power Input	Vendor to Specify		
4	Running current in Amps	Vendor to Specify		
5	Power Supply -230 V / 50 Hz / 1 Ph	Vendor to Confirm		
6	Rated EER - W / W	Vendor to Specify		
7	Indoor Unit Dimensions - (WxHxD) and weight	Vendor to Specify		
8	Outdoor Unit Dimensions - (WxHxD) and Weight	Vendor to Specify		
9	Noise level - Indoor - db (A)(not more than 50 db)	Vendor to Specify		
10	Refrigerant should be (R22/R134a/R404a/NON CFC)	Vendor to Specify		
11	Compressor should be rotary/scroll/screw	Vendor to Specify		
12	Length of Connecting Copper Pipe,Electrical cable should not be less than 4m/12 Ft	Vendor to Specify		
13	Wall Bracket, 4 KVA V-Guard Stabilizer should be supplied with machine, vendor to quote accordingly .	Vendor to Confirm		
14	Warranty: ONE YEAR for entire equipment and FOUR YEARS for compressor from the date of Commissioning	Vendor to Confirm		