

**ANNEXURE-PRE BID QUERIES**

<b>Sl. No.</b>	<b>Cl. Ref.</b>	<b>Tender Description</b>	<b>Bidder's Query</b>	<b>Clarification</b>
1	PE-TS-411-174A-A001 Volume II B Rev 00 Sheet 2 of 2 Raw Water Analysis Pg 193 of 806	TSS : 500 mg/l Turbidity : 16 NTU	There might be inconsistency between inlet TSS (500) and NTU (16). Bidder to consider 500 ppm TSS for design unless other information ?	Tender Specification is clear. Bidder to follow.
2	PE-TS-411-174A-A001 Volume II B Rev 00 Sheet 2 of 2 Clarified Water Analysis Pg 193 of 806	COC shall be 5.0	Please clarify "COC shall be 5.0." COC is about cooling tower cycle of concentration.	Bidder Understanding is correct.
3	Drawing Number : PE-DG-411-158A-A001 FLOW DIAGRAM FOR PRETREATMENT PLANT  PE-TS-411-174A-A001 Volume II B Rev 00 Sheet 4 of 6 1.5 Chemical house Pg 234/806	Lime dosing in clarifier  Lime dosing system for centrifuge (@30 ppm) on 100% basis	Flow diagram shows lime dosing in clarifier. No mention of lime dosing for centrifuge as in page 234/806. Please clarify dosing points for lime.	Please refer to the Ammendent-1.
4	PRE QUALIFIATION REQUIREMENTS Pg 1 of 1	A) supplier should have designing/ manufacturing capability and having testing facility (in house or outsourced)	Kindly clarify if a bidder who is not a manufacturer and a pure EPC contractor/ service provider is eligible to bid	Tender PQR is clear. Bidder to follow.
5	NIT Date 06.06..2015	22. BG should be in favour of BHEL-PSWR in place of PEM, vendors will be required to submit BGs to executing agency BHEL-PSWR	As communicated on phone, no EMD amount applicable and no BG to be submitted along with the BID. Only Performance contract BG to be submitted after award of contract. <u>Please approve.</u>	Bidder Understanding is correct.
6	GCC Rev. 06 Pg 6 of 22	6.0 VARIATION OF CONTRACT VALUE : Prices shall remain Firm (or with PVC as specified in NIT) for any increase or decrease in the Order/ Contract value (Ex- works) upto plus or minus 30% (for any amendment) within 2 years from the date of original PO unless specified otherwise in NIT. The Purchaser shall have the right to increase or decrease quantities and scope upto the above extent of value and Seller/ Contractor shall be bound to accept the same at the contracted prices without any escalation.	Please clarify	Clause no 6 of GCC Rev-06 is clear. Bidder to follow.

7	GCC Rev. 06 Pg 16 of 22	17.1 Insurance shall be arranged by BHEL.	please confirm which insurance shall be arranged by BHEL	For turnkey Package: Transit, unloading, storage, handling, erection and commissioning insurance is covered under BHEL scope.
8	PRE QUALIFIATION REQUIREMENTS Pg 1 of 1		Kindly clarify if an Indian subsidiary company using the technical PQR of its parent company is eligible to bid. Financial PQR submitted will be of Indian company, in whose name the bid will be submitted.	Tender PQR is clear. Bidder to follow.
9	PRE QUALIFIATION REQUIREMENTS Pg 1 of 1		Kindly clarify if bidder can use their similar Clariflocculator experience in other sectors in addition to the requirement in power plant or other industries e.g. refinery/ steel/ process/ commercial etc.	Tender PQR is clear. Bidder to follow.