

Project : Turbo Blower Station (Package no 10A)
Customer: NMDC, Nagarnar, Chhattisgarh
Consultant: MECON Limited
Enquiry ref: T7B1087113 dated 29.04.2015

SI No.	Section/Part/ Sub section	Page no.	Clause no.	Bid spec.	Bidders Query	BHEL clarification dated 18.05.2015
1	section C	7	Cl. 3.2	PEMC 05277	There is only one pump to be supplied for common skid as per specification. Kindly confirm	Skid shall contain only one pump. However, only one spare pump as loose supply for all the entire units (for all three skids together) is required.
2	Data sheet A	20	2.5	PEMC 05277	In CW Flow rate both normal as well as maximum only same value is mentioned. Kindly clarify	Normal flow shall be taken as 3125 m3/hr. Max. flow can be taken as with +10% margin.
3	Data sheet A	20	5.0	PEMC 05277	No specific drilling standard is specified in Flanges /counter flanges. Kindly mention in case of specific standard	AWWA C207 shall be followed
4					Only local control panel not PLC panel to be supplied by us. Kindly confirm	There is no PLC panel. Only LCP is to be supplied.