

ADDENDUM-3

DATE: 03-08-2016

E&C (Electrical) Contract for AHP for 2X660 MW Suratgarh STPS, Stage V, Unit 7&8

Tender Ref : 88/16/6015/RCD dtd. 15.06.2016.

1. Pre-bid Queries & clarifications have been uploaded on the website.
2. Any further addendum such issued carry part of the bidding documents and this will be available at the website from where the original documents have been received/ downloaded by the bidder. Hence bidders are requested to visit the website <https://bheleps.buyjunction.in> on regular basis.

For Further Queries if any, Contact:

For commercial :

Sh. Anand Aman

Sr. Engineer, Purchase/Works-1
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4134,
e-mail : ana@bhelisg.com

For Technical :

Sh. Venkateshwar Rao Vangala

Sr. Engineer/ PE/ Elect
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4077,
e-mail : vvr@bhelisg.com

PRE BID QUERY & REPLY

Enquiry No. : 88/16/6015/RCD dtd. 15.06.2016

Item : E&C (Electrical) Contract for AHP for 2X660 MW Suratgarh STPS, Stage V, Unit 7&8

Sl. No.	Bidder's Query	BHEL's Reply
1	<p>While executing a job agency involved has to pay following tax</p> <p>A. Service tax B. Swachh Bharat Tax C. Kisan Tax. D. State levied tax if applicable</p> <p>But only one tax has been taken into price format. Others are missing. Do we consider taxes other than Swachh Bharat tax will be paid by BHEL ISG?</p>	<p>The Service tax, Swachh Bharat Cess & Krishi Kalayan Cess shall be payable extra at actuals. However, bidder to indicate Swachh Bharat Cess to arriving total cost to BHEL as mentioned in price format. Bidder's to consider all other taxes in their offer as per clause no. 17.4 of commercial conditions of contract.</p>
2	<p>In BOQ in some of the items like A.4.4 to A.4.6 is different than col. C formula of $c = a * b$. When you click in the Total Basic Price respective cell it follow the formula but not in the mentioned items. It requires complete study how many items /cells are affected.</p>	<p>Quantity against item Sl. No. A.4.5 shall be read as 0 no's & 3 no's and Sl. No. A.4.6 shall be read as 3 no's. Bidder to consider the same in the price format while quoting.</p>
3	<p>Construction of Buried cable trench 1.2 Mtr wide and 1 Mtr deep including excavation , riddled soil filling above cables, placing precast concrete slab 150x250x4mm(thick)- 4no placed together along 150mm side throughout length of cable trench , soil backfilling above precast concrete slabs & ramming , erection of cable route marker & fixing cast iron plate with 4no bolts on top of marker at min 20m interval for Lighting Mast Cabling. Vendor scope involves supply/ preparation of precast concrete slabs of dimension 150x250x4mm(thick) required as per above scope, supply of trapezoidal concrete cable route marker(top face - 100x150, bottom face - 200x150 , height-450) , supply & fixing of cast iron plates of dimension 150x100x6(mm) with bolts on concrete route marker. Cast iron plates shall have embedding of cable route as intimated by BHEL Site incharge. Cable laying rates shall be payable separately. REFER BURIED TRENCH CONSTRUCTION AND LAYOUT ATTACHED AS ANNEXUREURE-8 LIGHTING MAST LAYOUT for typical trench cross section</p> <p>It is not possible to cast precast concrete slab 150x250x4mm(thick). Slab thickness of 4 mm should be 40 mm or more. There is mistake needs correction</p>	<p>Regarding item Sl. No. B.5, precast concrete slab dimension shall be considered as 150x250x40 mm(thick).</p>
4	<p>Item D4- 3C X 2.5 Cu - No's 2106</p> <p>As per our understanding 2106 is number of Cu lugs required for 3C X 2.5 Sq.mm Copper cable. Lugs are manufactured as per size of cable core and not as per number of cable core. Rate of 2.5 Sqmm cable core lug will be same whether it is 2 core or 10 core or 19 core. If it is different, Please clarify.</p> <p>A line of clarification will be highly redressing.</p>	<p>Qty mentioned in BOQ is the number of lugs only. Bidder may select suitable lug for each cable size and quote accordingly.</p>