



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 1 X 800 MW WANAKBORI TPP
PACKAGE : STATION LIGHTING SYSTEM.
Enquiry No. : PE/PG/WAN/E- E-5065/2015 Dtd. 15.10.2015

DATE: - 17.11.2015

Pre-Bid Clarifications -1

S. No.	Reference Clause of Tender documents	Pre-Bid Query	BHEL Reply
1.	BOQ SL.NO. 1.1.1 , 1.1.2, 1.3.1	In BOQ SL.NO. 1.1.1 you have shown 2 nos transformer for LDB-H(12) qty-22 nos. Thus transformer qty should be 44 nos for LDB H(12) for 2 nos incomer. But in SL.NO. 1.1.2 you have shown 22 nos transformer & as per specification AC LDB H12 & WDB-H(12) should have single incomer. Hence please confirm all AC LDB & WDB whether these will have single incomer or double incomer so that transformer qty could be decided.	Regarding BOQ Sl. No. 1.1.1 for Annexure-C & D, it is hereby confirmed that AC LDB & WDB are having Single Incomer as per specification. No. of transformers furnished against AC-LDB & WDB as 22 & 3 respectively shall be Unchanged. The description "including cubicles suitable for 2 nos. 100 kVA transformer" against sl. No. 1.1.1 & 1.3.1 of Annexure- C & D is a typographical error & may please be ignored.