



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 1 X 800 MW WANAKBORI TPP
PACKAGE : COOLING TOWER.
Enquiry No. : PE/PG/WAN/E-4865/15 Dtd.02.06.2015

DATE: - 23.07.2015

Pre-Bid Clarifications #4

S. No.	Reference Clause of Tender documents	Pre-Bid Query	BHEL Reply
1.	Clause no.3.02.02, Vol.IIB, Part 1,	Pile foundations are mentioned here. However, Table-1 at this clause on page no. 256 (of pdf file) presents that founding levels for open foundation of NDCT along with SBC available at each depth. We find that a SBC of 42 Ton/m ² is available at a depth of 5m from FGL. This gives us the option of opting for open foundation at 5m or greater depth from FGL as per design requirements. Hence, confirm that pile foundation is not mandatory for NDCT.	BHEL Reply vide Pre-bid clarification#2 (S.No.10) :- Work shall be done as per technical specifications Now to be Read as: - "Bidder shall provide the suitable Open Foundation or Pile foundation system as required. Pile foundation is not mandatory."