

| | |
|-------------------------|--|
| Client/Purchaser | Rajasthan Rajya Vidyut Utpadan Nigam Ltd. |
| Project | 2 X660 MW Suratgarh Super Critical Thermal Power Station Stage-5, Unit-7 & 8. |
| EPC Contractor | Bharat Heavy Electricals Ltd. (BHEL - Industrial Systems Group) |
| Pkg. | WAGON TIPPLER, SIDE ARM CHARGER, APRON FEEDER WITH DRIBBLE FEEDER, STACKER CUM RECLAIMER AND RECLAIMER |

| Sr No | RFQ reference | Vendor's query / comment | BHEL-ISG reply |
|-------|---|--|---|
| 1 | Section 08, Data sheets, Volume-III, Specifications - Apron feeder | The specification shows the capacity of Apron feeder of 2000 TPH (rated). The wagon tippler hopper opening is given as 1800 mm & apron feeder pan as 2000 mm. However looking to the capacity requirement the pan width minimum required would be 2200 mm. Please clarify / confirm. | Bidder to provide the width of the pan as system requirement. |
| 2 | Section 08, Data sheets, Volume-III, Specifications - Wagon tippler | We understand wagon tippler capacity is 20 tips per hour (guaranteed). Please confirm /clarify. Please provide us Wagon tippler hopper dimensional drawing in order to finalize the apron feeder dimensions. | Bidder to refer annexure-4/CHP DBR/Cl. No. 11/ SI.No. 02/ Sheet 22 of 35. i.e., 25 tips/hour (guaranteed). |
| 3 | Section 08, Data sheets, Volume-III, Specifications - Wagon tippler | The Side arm charger is required for hauling full rake of 58 wagons with 140 Tons weight (DFC wagons). Please note DFC wagons are not available at present. Please clarify / confirm the requirement. | Bidder to refer annexure-2/Vol-III/Sec-D*/Data sheet/ Cl.no. 4.0/ Sheet 26 of 37. i.e., All types of open wagons as stipulated in IS 10095. |
| 4 | Section 08, Data sheets, Volume-III, Specifications | We understand all equipment are to be designed for 25 % higher than rated capacity. Please clarify / confirm | Confirmed. Bidder to follow tender specifications. |
| 5 | Section 08, Data sheets, Volume-III, Specifications - Stacker cum reclaimer & Reclaimer | Please provide us dimensional details of stockpile for Indian as well as imported coal (Length x width / height) | Length of stockpile shall be 480mtrs. (including 20mtr gap between indian & imported stockpile - with 70:30 ratio resp.), width of 45 mtrs & height of 10 mtrs. Also, bidder to consider sufficient length of rails at both ends of stockpile for SCR & Reclaimer to reclaim/stack the coal from farthest point of stockpile. |
| 6 | Section 08, . Data sheets, Volume-III, Specifications - Stacker cum reclaimer & Reclaimer | Please clarify whether the bucket wheel diameter for stacker cum reclaimer as well as bucket wheel reclaimer is to be designed for peak reclaiming capacity or for rated capacity. Please clarify | Bidder to note that, system to be designed for design capacity. Bidder to follow tender specifications. |
| 7 | Section 08, Data sheets, Volume-III, Specifications - Stacker cum reclaimer & Reclaimer CTC - BHEL ISG - SUPPLY | The technical data sheets shows minimum boom length of 40 M while CTC shows 41 M. Please clarify which is to be followed . | Minimum boom length shall be of 41 mtrs. However, it shall be provided to meet system requirement. |

| Sr No | RFQ reference | Vendor's query / comment | BHEL-ISG reply |
|-------|---------------|---|--|
| 8 | | <p>With reference to above tender enquiry, we have to quote essential spares for the subject equipment. However the TCE tender document doesn't specify the essential spares list for reclaimer.</p> <p>Please let us know we have to quote spares as per TCE tender documents, or should we quote essential spares for reclaimer also taking base reference of stacker cum reclaimer.</p> <p>Also it may be the case that you might have combined essential spares list for both equipment (stacker cum reclaimer and reclaimer) under the heading stacker cum reclaimer in TCE tender document.</p> | <p>Bidder to follow tender specifications.</p> |
| 9 | | <p>Also please clarify below points related to apron feeders essential spares.</p> <p>a) Carrying roller - 4 Nos. - Requirement is clear to us we don't have any.</p> <p>b) Chain link with pins and bushes - 10 Sets - please confirm the qty in 1 set in numbers.</p> <p>c) Apron pans - 10 Sets - please confirm the qty in 1 set in numbers.</p> | <p>a) We understand that, bidder has understood the requirement clearly.</p> <p>b) One set means, one link with required number of pin & bushes and accordingly bidder to provide for 10 sets.</p> <p>c) Bidder to provide as per general standard practice.</p> <p>Also bidder to refer, Vol-II/Sec-C7 for further clarification on spares.</p> |