

TENDER SPECIFICATION

BHEL: PSSR: SCT: 1537

FOR

Handling at Site Stores / Storage yard, Transportation to Site of Work, Erection, Testing and Commissioning of Steam Turbine, Generator, Integral Piping, Pumps, CW Piping and other auxiliaries connected with the system and other BOI Including Supply and Application of Final Painting for **Unit-2** of 2 x 800 MW set

At

**Yermarus Thermal Power Station,
at Yermarus , Raichur Dist., Karnataka**

VOLUME –II

PRICE BID



BHARAT HEAVY ELECTRICALS LIMITED

(A Government of India Undertaking)

Power Sector – Southern Region

690, Anna Salai, Nandanam, Chennai – 600 035.

PRICE BID

BHARAT HEAVY ELECTRICALS LIMITED
(A Government of India Undertaking)
Power Sector, Southern Region
690, Anna Salai, Nandanam, Chennai – 35

Tender Specification No. BHEL: PSSR: SCT: 1537

For

Handling at Site Stores / Storage yard, Transportation to Site of Work, Erection, Testing and Commissioning of Steam Turbine, Generator, Integral Piping, Pumps, CW Piping and other auxiliaries connected with the system and other BOI Including Supply and Application of Final Painting for **Unit-2** of 2 x 800 MW set at Yermarus Thermal Power Station, at Yermarus , Raichur Dist., Karnataka

One set of Tender documents consisting of

- 1) Technocommercial Bid - 2 Copies
- 2) Price Bid - 2 Copies

Book Sl no

Issued to
M/s

Refer NIT for Last date of submission

Please note this tender document is not transferable

For and on behalf of
BHARAT HEAVY ELECTRICALS LIMITED

GENERAL MANAGER / HR and SCT

Place: Chennai -35
Date:

Tender Specification No.: BHEL: PSSR: SCT-1537

PRICE BID

YERMARUS 2 X 800 MW TPS RATE SCHEDULE FOR TG AND AUXS Unit -2

SL.No	DESCRIPTION OF WORK	AMOUNT IN RUPEES (Lumpsum)
1	<p>Supply of labour, all consumables and tools and tackles (except those specifically indicated as BHEL supply in the tender specification) required for erection, testing and commissioning of Turbo Generator set, associated auxiliaries, piping material etc. and supply & application of final painting of one unit at Yeramarus 2 x 800 MW TPS at Yeramarus, Raichur as per detailed description and nature of work enumerated in the tender specification including handling and other incidental works and modification and rectification works of TG set and auxiliaries, piping works required prior to and during pre assembly, erection, testing and commissioning of the entire system. This shall also include handling and transportation of the materials and equipments from storage yard to pre assembly yard and equipments from storage yard and pre assembly yard to place of erection.</p> <p>Approximate weight : 5814 MT</p>	<p>Amount in Rs.....</p> <p>(In words) Rupees.</p> <p>.....</p>

SIGNATURE OF THE TENDERER

PRICE BID

Note :

1. The total weight indicated in rate schedule is only approximate and is liable for variation / alteration at the discretion of BHEL.
2. The total lumpsum value includes all charges towards pre-heating, welding, post heating, heat treatment and NDT all joints involved in this work including that of all joints of site routed piping, condenser and any other joints.
3. Radiography and other NDT testing such as LPT, UT and MPI will have to be arranged by contractor at their cost.
4. In case of variation in weight beyond +15% i.e., beyond 6686 MT the quantity exceeding +15% of the tendered quantity will be paid at the average tonnage rate arrived at by dividing the Lumpsum Quoted / accepted value by 6686 MT
5. Tenderers are required to quote their rates, only in the price bid (VOL II) provided by BHEL. Quoting of rates in any other form / formats will not be entertained.
6. Refer GCC chapter-1, CL 1.4 for price discrepancy.