

Enquiry No - E 7190273

BHARAT HEAVY ELECTRICALS LIMITED, JHANSI

WORKS ENGG. & SERVICES DEPTMENT

SPECIFICATION FOR DISTRIBUTION BOARD

1. Triple pole neutral 12 way 30 Amp. MCB distribution board with metal door complete with 12 numbers Triple pole MCB (C curve) rating 30/32 Amp. (make - Legrand/ L&T/ C&S/ schneider only). Distribution board should be supplied with one number triple pole ICTPN fuse switch unit CH type rating 100 Amp. with 3 Nos. 100 Amp. HRC fuses TC type (make - EE power control only) and suitable cable termination chamber.

Quantity - 12 Nos.

2. MCB distribution board with 20 Amp. Single phase industrial socket and one number single phase 20 Amp. MCB. Legrand/ L&T/ C&S/ schneider make only)

Quantity - 50 Nos.

3. Triple pole neutral 8 way 63 Amp. fuse distribution board (CH63TN8) with 24 Nos. 63 Amp. HRC fuse TIS type. Distribution board should be supplied with one number triple pole ICTPN fuse switch unit rating 200 Amp. with 3 Nos. 200 Amp. HRC fuses TF type (make - EE power control only).and suitable cable termination chamber.

Quantity - 10 Nos.

4. Triple pole neutral 6 way 100Amp. fuse distribution board (9SM100 TN6) with 100 Amp. HRC fuse TCP type . Distribution board should be supplied with one number triple pole ICTPN fuse switch unit rating 315 Amp. CH type with 3 Nos. 300 Amp. HRC fuses TKF type (make - EE power control only).and suitable cable termination chamber.

Quantity - 8 Nos.

5. Triple pole ICTPN fuse switch unit rating 315 Amp. with 3 Nos. 300 Amp. HRC fuses (make - EE power control only).

Quantity - 8 Nos.

6. Triple pole ICTPN fuse switch unit rating 200 Amp. with 3 Nos. 200 Amp. HRC fuses (make - EE power control only).


Quantity - 8 Nos.


7. Triple pole ICTPN fuse switch unit rating 100 Amp. with 3 Nos. 100 Amp. HRC fuses (make - EE power control only).

Quantity - 24 Nos.

8. Metal four pole enclosure (distribution board) suitable for mounting 4 Nos. 16 Amp. MCB. The enclosure shall be complete with 4 Nos. 16 Amp. SP MCB. (make - Legrand/ L&T/ C&S/ schneider only).

Quantity - 100 Nos.


Sujeet Srivastava
Sr. Engineer (WE&S)


Inder Mathur
Manager (WE&S)

S.J.Chakraborty
DGM (WE&S)