


SUPPLY OF 1.5 TR ROTARY COMPRESSOR		DT:	
Sl.	Specifications / Description for BHEL Requirement	Deviations	Remarks
1	Compressor should be rotary only	Vendor to confirm	
2	Compressor should be suitable for Power Supply -230 V / 50 Hz / 1 Ph	Vendor to confirm	
3	Compressor should be Suitable for R22 Refrigerant	Vendor to confirm	
4	Warranty: ONE YEAR for COMPRESSOR from the date of Supply.	Vendor to confirm	


A. KUMARA AYYAPPA
Sr. Engineer/M&S(Air Conditioning)
हैदराबाद, हैदराबाद, हैदराबाद
Sr. Engineer/M&S(Air Conditioning)
हैदराबाद, हैदराबाद, हैदराबाद