

**Qualification criteria: Only offer of OEM or their authorised dealer is acceptable to us.**

**SPECIFICATION FOR DISTRIBUTION BOARD**

1	<b>ITEM NO. 01</b>	<b>Qty - 07 Nos</b>	
A	<b>GE -MAKE, FUSE DISTRIBUTION BOARD 08 WAY 63 AMP., 3 PH.</b> [( GE-LIST NO. SM63TN8) (GE-CODE REF -SGV8620008)] ( INCLUDED SUITABLE 24 NO. 63 AMP. HRC FUSE-TIS, FUSE HOLDER AND FUSE BASE) REF: STANDARD IS2675-1983  OR EQUIVELENT OF SIEMENS, L&T, HAVELLS , C&S MAKE ONLY		VENDER TO SPECIFY THE MAKE & CONFIRM
B	<b>GE- MAKE, WALL MOUNTING TYPE COMBINATION FUSE SWITCH UNIT 200AMP.TYPE :</b> CH(CAST IRON ENCLOSURE TPN), [GE-LIST NO. CH2003N(U), GE-CODE REF ( PGH8166102)] INCLUDED SUITABLE 03 NO. HRC FUSE-TF (200 AMP)  OR EQUIVELENT OF SIEMENS, L&T,HAVELLS , C&S MAKE ONLY		VENDER TO SPECIFY THE MAKE & CONFIRM
C	SUITABLE CABLE TERMINATION CHAMBER		VENDER TO CONFIRM
	ALL ABOVE THREE ITEMS MUST BE MOUNTED ON 35X35X 05 MM MS ANGLE FRAME		VENDER TO CONFIRM

2	<b>ITEM NO. 02</b>	<b>Qty- 06 Nos</b>	
A	<b>GE -MAKE, FUSE DISTRIBUTION BOARD 06 WAY 100 AMP., 3 PH.</b> [( GE-LIST NO. SM100TN6) (GE-CODE REF -SGV8625006)] (INCLUDED SUITABLE 18 NO. 100 AMP. HRC FUSE-TCP, FUSE HOLDER AND FUSE BASE) REF: STANDARD IS2675-1983  OR EQUIVELENT OF SIEMENS,L&T,HAVELLS , C&S MAKE ONLY		VENDER TO SPECIFY THE MAKE & CONFIRM
B	<b>GE- MAKE, WALL MOUNTING TYPE COMBINATION FUSE SWITCH UNIT 315AMP. TYPE :</b> CH(CAST IRON ENCLOSURE TPN), [GE-LIST NO. CH3153N(U), GE-CODE REF ( PGH8170102)] INCLUDED SUITABLE 03 NO. HRC FUSE-TKF (300/315 AMP)  OR EQUIVELENT OF SIEMENS, L&T, HAVELLS , C&S MAKE ONLY		VENDER TO SPECIFY THE MAKE & CONFIRM
C	SUITABLE CABLE TERMINATION CHAMBER		VENDER TO CONFIRM
D	ALL ABOVE THREE ITEMS MUST BE MOUNTED ON 35X35X 05 MM MS ANGLE FRAME		VENDER TO CONFIRM