



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT:LPT-A1202:TCN-01

Date: 04-06-2011

Sub	Tender change notice (TCN) 01.	
Job	(i) Erection, commissioning etc of Electrical System; (ii) Erection, commissioning etc of control & instrumentation (C&I) System; (iii) Engineering/ design, manufacturing/ procurement, supply, erection, commissioning etc of Ventilation System and (iv) Engineering/ design, manufacturing/ procurement, supply, erection, commissioning etc of Plant Illumination System for 53 MW Combined Cycle Power Plant at Lepetkata, BCPL, Assam.	
Ref	1.0	Tender no PSER:SCT:LPT-A1202:11.
	2.0	BHEL's NIT, vide reference no PSER:SCT:LPT-A1202:2408, dated 17-05-11.
	3.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Extension of due date of submission of offer from 08-06-11 to **20-06-2011 (15-00 hrs)**.
- 2.0 In terms of sl no 1.4, page 1 of 11 of NIT, closing date of sale of tender from BHEL PSER office shall be read as 19-06-11.
- 3.0 Amendment/ modification/ clarification as per enclosed Annexure-A
- 4.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 5.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

Engineer (SCT)

Encl

- 1.0 As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

JOB (i) Erection, commissioning etc of Electrical System; (ii) Erection, commissioning etc of control & instrumentation (C&I) System; (iii) Engineering/ design, manufacturing/ procurement, supply, erection, commissioning etc of Ventilation System and (iv) Engineering/ design, manufacturing/ procurement, supply, erection, commissioning etc of Plant Illumination System for 53 MW Combined Cycle Power Plant at Lepetkata, BCPL, Assam.
TENDER NO - PSER:SCT:LPT-A1202:11

SL NO	AMENDMENT/ MODIFICATION/ CLARIFICATION		
1.0	NIT		
	SL NO	QUERY	CLARIFICATION
	Page 8 of 11	Kindly provide us the Address and contact information of 1) M/s. Engineers Fabricators & 2) M/s.KPC India Ltd. for quoting our best price.	Approved vendor for the ventilation system are as follows: 1) ADVANCE VENTILATION PVT LTD 2) BLUESTAR LTD 3) C DOCTOR PVT LTD 4) DUSTVEN PVT LTD 5) S K SYSTEMS PVT LTD 6) VOLTAS LTD This also supercedes cl no 2.0.0 of BHEL spec , PEMC 02459 Rev 01.
2.0	Volume-IF- SERVICE		
	CLAUSE NO	QUERY	CLARIFICATION
	9.15	We have considered Flexible GI conduit as per BOQ. Please clarify as to why supply of the item is again mentioned in the scope of service.	The scope generally covers supply and execution of flexible conduit to be considered for illumination work. However, bidder shall quote price for supply part & service part separately under respective schedules of Volume-IIIA.
	18.1.13/ 18.2.6	Clause No.18.1.13 & 18.2.6 are contradictory. Please clarify	Commissioning of all auto control loops in contractor scope.
	18.5.11	Normally commissioning of total system (MMI) should be in System supplier scope. Please clarify.	It will be done by BHEL, but necessary manpower assistance is in vendor's scope.
	18.1.11/ 18.1.12	Normally Software programming services should be in system supplier's scope. Please clarify	Normally Software programming services should be in system supplier's scope & shall be done by BHEL. For calibration and system integration checks during commissioning etc, contractor shall provide manpower assistance.
	28.7	Please provide us the information of approximate no. of terminations other than HT cables	Approximate termination for LT power : 2000 cables Control : 3350 cables Signal: 4000 cables (only for guidance purpose, payment shall be as per respective schedules of Volume-IIIA)

	53.0	As per clause 51.2 project duration to be considered is 15 months. Project completion date mentioned in cl. No. 53. is 14-08-12 (ie. Only 14 months remain after bid opening). Hence, Please clarify.	Project completion date mentioned in cl. No. 53. as 14-08-12 to be treated as deleted.
3.0	VOLUME-III		
	SL NO	QUERY	CLARIFICATION
	3.24 OF SCH-5.0	Technical details of cable glands and lugs (Make, Type etc). not provided with the tender.	The Make of the gland & lugs 1.Baliga lighting equipment 2.Comet brass products 3.Comet industries 4.FCG flameproof control gear pvt. ltd. 5.FCG Power Industries. 6.Flameproof Equipment. 7.Flexpro Electrical 8.Prompt Engineers 9.Standard Metal Industries 10.Sudhir Switchgear.
4.0	General		
4.1	Bidder shall submit offer strictly in compliance with technical specification and tender terms along with amendment/ clarifications issued till date within the due date.		
4.2	All other terms & conditions shall remain unchanged.		

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	(i) Erection, commissioning etc of Electrical System; (ii) Erection, commissioning etc of control & instrumentation (C&I) System; (iii) Engineering/ design, manufacturing/ procurement, supply, erection, commissioning etc of Ventilation System and (iv) Engineering/ design, manufacturing/ procurement, supply, erection, commissioning etc of Plant Illumination System for 53 MW Combined Cycle Power Plant at Lepetkata, BCPL, Assam.	
Ref	1.0	Tender no PSER:SCT:LPT-A1202:11.
	2.0	BHEL's NIT, vide reference no PSER:SCT:LPT-A1202:2408, dated 17-05-11.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:LPT-A1202:TCN-01, dated 04-06-11.
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)