



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 01

Ref: PSER:SCT:NKP-B1744:TCN-01

Date: 25-05-2016

Sub	Tender change notice (TCN) 01	
Job	Erection, Testing and Commissioning of Main Boilers and Auxiliaries covering Structures, Pressure Parts, Rotating Machines, Ducts, ESP, Fuel firing system, Various SG/Critical/Misc. Piping etc. along with integrated Mill Bunker Structures of Unit # 2 including fabrication , erection and painting of Fire Water Storage Tanks at of 3x660 MW North Karanpura Project, Jharkhand.	
Ref	1.0	Tender No. PSER:SCT: NKP-B1744:16
	2.0	BHEL's NIT, vide reference no PSER:SCT:NKP-B1744:5029 Date: 20-05-2016
	3.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarification to bidder's query as per attached Annexure-A.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

SR.ENGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Erection, Testing and Commissioning of Main Boilers and Auxiliaries covering Structures, Pressure Parts, Rotating Machines, Ducts, ESP, Fuel firing system, Various SG/Critical/Misc. Piping etc. along with integrated Mill Bunker Structures of Unit # 2 including fabrication , erection and painting of Fire Water Storage Tanks at of 3x660 MW North Karanpura Project, Jharkhand.	
Ref	1.0	Tender No. PSER:SCT: NKP-B1744:16
	2.0	BHEL's NIT, vide reference no PSER:SCT:NKP-B1744:5029 Date: 20-05-2016
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:NKP-B1744:TCN-01, dated 25-05-2016.
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

ANNUXURE-A TO TCN-01

Erection, Testing and Commissioning of Main Boilers and Auxiliaries covering Structures, Pressure Parts, Rotating Machines, Ducts, ESP, Fuel firing system, Various SG/Critical/Misc. Piping etc. along with integrated Mill Bunker Structures of Unit # 2 including fabrication , erection and painting of Fire Water Storage Tanks at of 3x660 MW North Karanpura Project, Jharkhand.

Tender No. PSER:SCT: NKP-B1744:16

Sl. No.	Reference Cl.No. of Bidding Document	Bidder's query	Existing clause	Modified clause
1	Vol-1F-Rev.-0-TCC, Cl. No. 5.44.23	"As per clause No. 5.44.23 (TCC) indicates M/s BHEL shall provides with free of charges " and "As per Appendix II (TCC) - Major Tools and Plants & MMDs to be delpyed by the Contractor (Page 86 of 90) indicates is in Contractor Scope". Please Clarify.	<p>FACILITY TO BE PROVIDED BY BHEL FOR P-91 WELDING, FREE OF CHARGES</p> <p>Required No. of Induction Heating Machines with accessories.</p> <p>2. The following consumables :</p> <p>(i) Annealing Cables</p> <p>(ii) Compensating Cables</p> <p>3. Welding electrodes for P-91 welding.</p> <p>4. Digital Temperature indicator.</p> <p>The Induction heating equipment shall be drawn from BHEL stores, transported, installed and commissioned wherever required at site. For routine and breakdown maintenance, Contractor shall have to deploy sufficient Manpower, Tools & Plants within his quoted rate.</p> <p>The contractor shall provide electrical cables and switches required. All the equipment shall be protected by providing covers or sheds at site by the contractor within the quoted rate. Any loss / damage of equipment / tools by the contractor shall be recovered from the contractor.</p>	<p>DEPLOYMENT OF INDUCTION HEATING MACHINES BY THE BIDDER :</p> <p>FOLLOWINGS SHALL BE ARRANGERD BY THE CONTRACTOR FOR P 91 WELDING, AT THEIR OWN COST.</p> <p>1. Required No. of Induction Heating Machines with accessories shall be deployed by thecontractor.. However, initially 05 nos Induction Heating Machines are required to be deployed at site.</p> <p>2. the following consumables shall be in the scope of supply by the contractor. :</p> <p>i. Annealing Cables</p> <p>ii. Compensating Cables</p> <p>3. Welding electrodes for P-91 welding shall be supplied by BHEL at free of Cost.</p> <p>4. "Digital Temperature indicator" shall be in the arranged/provided by the contractor.</p> <p>Vendor shall maintain required facilities for routine and breakdown maintenance of the Induction Heating Machine including availability of some spare Induction Heating machines at site so that site work would not suffer due to break-down of the running equipment.</p> <p>The contractor shall provide electrical cables and switches etc. as required for operating the Induction Heating Machine. All the equipment shall be protected by providing covers/canopies or sheds at site by the contractor.</p>