



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER: SCT: BRM-E1628: TCN-01

Date: 25-11-2014

Sub	Tender Change Notice (TCN)- 01.	
Job	Electrical-2: Erection, laying/ installation, testing, commissioning, handing over, etc of panel, motor, HT/ LT switch gear, cable, cable tray & accessories, other misc equipments, etc for 2x250 MW Barauni Extension Project at Begusarai, Bihar.	
Ref	1.0	Tender no PSER:SCT: BRM-E1628:14
	2.0	BHEL's NIT, vide reference no PSER:SCT: BRM-E1628:4076 Date: 20-11-2014
	3.0	Other References, if any.

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting the offer.

1. Clarification against bidders query against [volume- IIIA & TCC is attached in Annexure-A to TCN-01.](#)
2. [Revised 'No deviation certificate'](#) is attached. Bidder to submit 'No deviation certificate' as per attached format only.
3. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DGM(SCT)

Encl:

1.0 As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

JOB		Electrical-2: Erection, laying/ installation, testing, commissioning, handing over etc of panel, motor, HT/ LT switch gear, cable, cable tray & accessories, other misc equipments, etc for 2x250 MW Barauni Extension Project at Begusarai, Bihar.		
TENDER NO		PSER:SCT: BRM-E1628:14		
Sl no	Reference clause of tender document	Existing provision	Bidder's query	BHEL's clarification
1	VOLUME-IIIA PRICE SCHEDULE-2 SL No.13 &14	LT SWITCHGEAR BOARD,PANEL & DCDB	Please Provide the Dimensions (L X W X H) and Weight of Panels/Boards	Shall be provided during execution
2	VOLUME-IIIA PRICE SCHEDULE-3 SL No.1.1	6 MM THICK BLACK CHEQUERED RUBBER MAT OF VOLTAGE CLASS UP TO 11 KV, SIZE 1M (W) x 2M (L) EACH FOR LAYING INFRONT OF SWITCHGEAR UPTO 11KV (MANUFACTURER'S CERTIFICATE AS PER IS STANDARD IS TO BE PROVIDED)	The specified type (1M X2 M X6MM Thick) rubber mat is as per IS5424:1969. IS 5424:1969 is superseded and new IS No. 15652:2006 (1MX2MX2.5MM Thick) has been introduced w.e.f. 01 Nov 2007. Copy Govt. of India Gazette notification is enclosed herewith. Please confirm Rubber Mats as per IS 15652:2006 is to be supplied for this project.	Rubber Mats as per IS 15652:2006 is acceptable
2	TCC VOLUME-IF- CML-R-0 Clause No.41	TAXES AND DUTIES	1) Since this is only an erection service contract, kindly confirm that Works Contract Tax (WCT) is not applicable for this contract. 2) Since there is no Building Construction works involved in this project, please clarify if the 1% Cess against BOCW act is applicable for electrical package also.	Levying W.C.T. is as per state law. Whether a job attracts W.C.T. or not, depends upon the scope of job & is purely a matter of State Sales Tax Authority. Even a miniscule percentage of supply in the entire scope of job attracts W.C.T. to that extent. Hence, confirmation from BHEL regarding applicabilityof W.C.T.is an absurd preposition. Each & every dealer is a separate legal entity and he has to face Department based on his scope of jobs, amount of supply & services involved. For both SL. NO.1&2-Please refer Clause No:41.2

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Electrical-2: Erection, laying/ installation, testing, commissioning, handing over, etc of panel, motor, HT/ LT switch gear, cable, cable tray & accessories, other misc equipments, etc for 2x250 MW Barauni Extension Project at Begusarai, Bihar.	
Ref	1.0	Tender no PSER:SCT: BRM-E1628:14
	2.0	BHEL's NIT, vide reference no PSER:SCT: BRM-E1628:4076 Date: 20-11-2014
	3.0	BHEL's TCN-01,vide reference no PSER: SCT: BRM-E1628: TCN-01 Date: 25-11-2014
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)