



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

( भारत सरकार का उपक्रम )

**BHARAT HEAVY ELECTRICALS LIMITED**

(A Govt. of India Undertaking)

**TCN – 01**

Ref: PSER:SCT: TST-H1681:TCN-01

Date: 17-07-2015

Sub	Tender change notice (TCN) 01	
Job	Providing On Monthly Hire Basis Two Nos. 250 KVA Silent Diesel Generating Sets with Operator, Maintenance and Running including supply of Fuel on Per KWhr basis to provide uninterrupted supply of Construction Power At BHEL's Teesta Low Dam Stage 4 HEP Site, Kalijhora, Distt: Darjeeling, West Bengal.	
Ref	1.0	Tender no PSER:SCT:TST-H1681:15.
	2.0	BHEL's NIT, vide reference no PSER:SCT:TST-H1681: 4579 Date: 08-07-2015
	3.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarification to bidder's queries is attached as per Annexure-A to TCN 01
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

DY MGR (SCT)

Encl

- 1.0 Annexure-A to TCN -01
- 2.0 Revised 'No deviation certificate' format.

पावर सेक्टर पूर्वी क्षेत्र ( मुख्यालय )

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
 Power Sector - Eastern Region,  
 Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
 Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Providing On Monthly Hire Basis Two Nos. 250 KVA Silent Diesel Generating Sets with Operator, Maintenance and Running including supply of Fuel on Per KWhr basis to provide uninterrupted supply of Construction Power At BHEL's Teesta Low Dam Stage 4 HEP Site, Kalijhora, Distt: Darjeeling, West Bengal.	
Ref	1.0	Tender no PSER:SCT:TST-H1681:15.
	2.0	BHEL's NIT, vide reference no PSER:SCT:TST-H1681: 4579 Date: 08-07-2015
	3.0	BHEL's TCN-01, vide reference PSER:SCT: TST-H1681:TCN-01, dated 17-7-15
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

**Providing On Monthly Hire Basis Two Nos. 250 KVA Silent Diesel Generating Sets with Operator, Maintenance and Running including supply of Fuel on Per KWhr basis to provide uninterrupted supply of Construction Power At BHEL's Teesta Low Dam Stage 4 HEP Site, Kalijhora, Distt: Darjeeling, West Bengal.**

**Tender no :PSER:SCT:TST-H1681:15.**

**ANNEXURE-A TO TCN-01**

Sl. No.	Reference clause of tender document	Existing provision	Bidder's query	BHEL's clarification
1	-	-	Please confirm your requirement is for genset with AMF panel or manual control panel	Genset with AMF Panel not required
2	-	-	Your requirement is for 250KVA Genset likely to be run on continuous basis. In that case the genset can not be loaded more than 200KVA. In case you want 250KVA continuous load, we may have to go for higher rated Genset. Kindly confirm	Tender requirement is for 02 nos. 250 KVA (Continuous Rated Capacity) DG Set.
3	-	-	As per the tender period of operation is 14 months with a clause that contract can be terminated any time with one month notice. We would like to inform you that the rental charges are based on the period of contract, so kindly give us an indication about the minimum period that you would require the genset.	No change in Bid Condition.
4	-	-	The genset requires a level concrete surface of approximate size 5 meters X 2 meters for installation. BHEL shall provide the same.	Included in Bidder's scope