



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT: SNG-I1579:TCN-01

Date 20-08-2014

Sub	Tender Change Notice (TCN)- 01.	
Job	Erection, Testing, Commissioning of complete C&I (Control & Instrumentation) system including all max. System & Panels MMI system pertaining to Boiler & Aux, TG & Aux and Station C&I, and C&I of Balance system / item for 2x600 MW Singareni Thermal Power Project , Andhra Pradesh.	
Ref	1.0	Tender no PSER:SCT: SNG-I1579:14
	2.0	BHEL's NIT, vide reference no PSER:SCT: SNG-I1579:3855 Date: 04-08-2014
	3.0	Other References, if any.

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting the offer.

- 1) Clarification is attached vide Annexure-A to TCN-01.
- 2) Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

Sr.Engineer (SCT)

Encl: As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

JOB:ERECTION, TESTING, COMMISSIONING OF COMPLETE C&I (CONTROL & INSTRUMENTATION) SYSTEM INCLUDING ALL MAX. SYSTEM & PANELS MMI SYSTEM PERTAINING TO BOILER & AUX, TG & AUX AND STATION C&I, AND C&I OF BALANCE SYSTEM / ITEM FOR 2X600 MW SINGARENI THERMAL POWER PROJECT , ANDHRA PRADESH.(TENDER NO PSER:SCT:SNG-I1579:14)

ANNEXURE-A TO TCN-01

CLARIFICATION OF BIDDER'S QUERY

SL NO	REFERENCE CLAUSE OF TENDER DOCUMENT	EXISTING PROVISION	BIDDER'S QUERY	BHEL'S CLARIFICATION
1.0	SL NO F OF PRICE SCHEDULE-VOLUME-III, REV-00	PANELS & SYSTEMS AND PLANT MONITORING SYSTEM	KINDLY PROVIDE DETAILED SPECIFICATIONS LIKE WEIGHT AND DIMENSIONS OF EACH PANEL	DIMENSION: (800X800X2295)MM WEIGHT:1 MT(APPROX)
2.0	SL NO G OF PRICE SCHEDULE-VOLUME-III, REV-00	OTHER PANELS / RACKS	KINDLY PROVIDE DETAILED SPECIFICATIONS LIKE WEIGHT AND DIMENSIONS OF EACH PANEL / RACK	THIS SHALL BE PROVIDED DURING EXECUTION.
3.0	SL NO K1 OF PRICE SCHEDULE-VOLUME-III, REV-00	UPS SYSTEM WITH ACDB	KINDLY PROVIDE RATING & DIMENSIONS OF UPS AND ACDB	UPS (150KVA APPROX .) WITH ACDB (2NO.),CHARGER , ISOLATION SWITCH AND INVERTER
4.0	SL NO K2 OF PRICE SCHEDULE-VOLUME-III, REV-00	BATTERY FOR UPS WITH ALL ACCESSARIES	KINDLY PROVIDE BATTERY RATING & NUMBER OF CELLS	BATTERY BANK(EACH BANK CONTAINS 291 CELLS) WITH ALL ACCESSORIES

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Erection, Testing, Commissioning of complete C&I (Control & Instrumentation) system including all max. System & Panels MMI system pertaining to Boiler & Aux, TG & Aux and Station C&I, and C&I of Balance system / item for 2x600 MW Singareni Thermal Power Project , Andhra Pradesh.	
Ref	1.0	Tender no PSER:SCT: SNG-I1579:14
	2.0	BHEL's NIT, vide reference no PSER:SCT: SNG-I1579:3855 Date: 04-08-2014
	3.0	BHEL's TCN-01, vide reference no PSER:SCT: SNG-I1579:TCN-01 Date 20-08-2014
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691