



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT:SDG-M1286:TCN-01

Date: 06/01/2012

Sub	Tender change notice (TCN) 01	
Job	Design , engineering, manufacturing, supply/ delivery, storage & handling, erection, commissioning, trial run, handing over to customer etc of Ventilation System for 2x500 MW unit at Sagardighi STPP, WB.	
Ref	1.0	Tender no PSER:SCT:SDG-M1286:11
	2.0	BHEL's NIT, vide ref no PSER:SCT: SDG-M1286:11 Dated 21/12/2012
	3.0	Other references (if any).

With reference to above, following points , relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 BHEL clarification to bidders query is attached as per Annexure-A to TCN-01.
- 2.0 Revised `No deviation certificate' is attached. Bidder to submit `No deviation certificate' as per attached Format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGR (SCT)

Encl

- 1.0 BHEL clarification : Annexure-A to TCN-01
- 2.0 Revised `No deviation certificate' format.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

Tender no PSER:SCT:SDG-M1286:11
BHEL Clarification : Annexure-A to TCN-01

Sl. No.	Bidders Queries	BHELs Clarification
01.	Whether Centrifugal fan to be considered 2 nos. (i.e 1W +1S) for each Air Washer & UAF unit or not.	Refer clause no. 5.1.1 & 5.1.2 of section c of technical specification.
02.	Thickness of G.I sheet will be selected based on size of duct.	Refer clause no. 5.5.2 of section C of technical specification.
03.	Heat Load calculation to be considered or not.	Bidder to submit calculation during detailed engineering.
04.	Softcopy (Auto CAD version) drawings for all buildings to be provided for duct insulation.	Duct insulation qty. shall be as per suggestive price format , since quantity is variable and shall be paid as per actual erected at site.
05.	Make up water requirement & supply to Air washer & UAF to be considered in our scope or not.	Make up water shall be provided by bhel at all air washer room & uaf location, further distribution and piping shall be provided by the bidder.
06.	We observed as per volume –III SCH-3 supply break up that Centrifugal Fan capacity with Air washer & other Axial Fan capacity, quantity of ducting, grille, damper, louver are defined. Please confirm whether we shall consider the same quantities in our scope of supply or we have to consider the ventilation system on turnkey basis by including complete design & calculation.	Ventilation system shall be on turnkey basis. Bidder to quote as per price format. Variable items (* marked in suggestive price format)shall be paid as per actual qty. erected at site.
07.	Acceptance of self made items	Being an open tender , offer will be evaluated w.r.t PQR on receipt of their technical bid . Further Self made items shall be subject to customer approval.

**FORMAT FOR NO DEVIATION CERTIFICATE
FOR PACKAGE –A (To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design , engineering, manufacturing, supply/ delivery, storage & handling, erection, commissioning, trial run, handing over to customer etc of Ventilation System for 2x500 MW unit at Sagardighi STPP, WB.	
Ref	1.0	Tender no PSER:SCT:SDG-M1286:11
	2.0	BHEL's NIT, vide ref no PSER:SCT: SDG-M1286:11 Dated 21/12/2012
	3.0	BHEL's TCN-01 , vide ref no PSER:SCT:SDG-M1286:TCN-01 Dated 06/01/2012.
	4.0	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, Integrity Pact (If applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)