



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT: IIS-M1315:TCN-01

Date: 29-03-2012

Sub	Tender change notice (TCN) 01.	
Job	Fabrication of bends and erection / commissioning of cold blast piping along with filter & silencer equipment of 3x18 MW Power & Blowing station for IISCO steel plant, Burnpur, W.B.	
Ref	1.0	Tender no PSER:SCT:IIS-M1315:12
	2.0	BHEL's NIT, vide reference no PSER:SCT:IIS-M1315:2740, dated 12-03-2012.
	3.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Extension of due date of submission of offer from 02-04-2012 to **09-04-2012 (15-00 hrs)**.
- 2.0 Amendment/ modification/ clarification to tender terms as per enclosed Annexure-A.
- 3.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 4.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGR (SCT)

Encl

- 1.0 As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Fabrication of bends and erection / commissioning of cold blast piping along with filter & silencer equipment of 3x18 MW Power & Blowing station for IISCO steel plant, Burnpur, W.B.	
Ref	1.0	Tender no PSER:SCT:IIS-M1315:12.
	2.0	BHEL's NIT, vide reference no PSER:SCT:SDG-E1222:2439, dated 23-06-2011.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT: IIS-M1315:TCN-01, dated 29-03-2012.
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

JOB	Fabrication of bends and erection / commissioning of cold blast piping along with filter & silencer equipment of 3x18 MW Power & Blowing station for IISCO steel plant, Burnpur, W.B.
TENDER NO	PSER:SCT:IIS-M1315:12

SL NO	AMENDMENT/ MODIFICATION/ CLARIFICATION		
1.0	Volume-IF (Technical Conditions of Contract)		
	CLAUSE NO	EXISTING CLAUSE/PROVISION	MODIFIED/CHANGED CLAUSE/PROVISION
1.1	3.0	CONSTRUCTION POWER	CONSTRUCTION POWER & WATER
1.2	6.0	Completion Period for the tendered scope of work shall be 4(Four) Months.	Thus total Completion Period for the tendered scope of work shall be 4(Four) Months.
1.3	7.13	Welding of root valves with small length of piping to the pressure, flow and level tapping points on piping or flow nozzles/orifices/metering elements fixed on piping, welding of supports/guides/restraints as per specifications/drawings or as per directives of BHEL Engineer.	Welding of root valves along with counter flanges & small length of piping to the pressure, flow and level tapping points on piping or flow nozzles/orifices/metering elements fixed on piping, welding of supports/guides/restraints as per specifications/drawings or as per directives of BHEL Engineer.
1.4	7.14	Welding of blanks if required on a temporary basis, shall have to be done as per the system requirements.	Welding of blanks if required on a temporary basis, shall have to be done as per the system requirements. Blanks may have to be cut from rectangular plates to the required shapes.
1.5	7.16	Testing of the welders shall have to be conducted by the contractor at site with proper arrangements for the same before deputing any welder.	Testing of the welders shall have to be conducted by the contractor at site with proper arrangements along with test piece for the same before deputing any welder.
1.6	8.3	Any consumables (e.g. electrodes, filler wires) which are to be used during welding must be procured from BHEL approved suppliers with test certificate.	Any consumables (e.g. electrodes, filler wires) which are to be used during welding must be procured from BHEL approved suppliers with test certificate. Test certificates may have to be shown to BHEL.
2.0	General		
2.1	All other terms & conditions shall remain unchanged.		
2.2	Bidder shall submit offer strictly in compliance with technical specification and tender terms along with amendment/ clarifications issued till date within the due date.		