



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

( भारत सरकार का उपक्रम )

**BHARAT HEAVY ELECTRICALS LIMITED**

(A Govt. of India Undertaking)

**TCN - 01**

Ref: PSER:SCT:DPL-M1371:TCN-01

Date: 18-07-2012

Sub	Tender change notice (TCN) 01.	
Job	Design, engineering, manufacturing, supply/ delivery, storage & handling, erection, commissioning, trial run, handing over to customer, etc of Mill Reject Handling System for 1x250 MW unit at DPL, Durgapur, WB..	
Ref	1.0	Tender no PSER:SCT:DPL-M1371:12.
	2.0	BHEL's NIT, vide reference no PSER:SCT:DPL-M1371:2862, dated 29-06-2012.
	3.0	Other references (if any).

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Amendment/Clarification to tender as per enclosed Annexure-A.
- 2.0 Due date of submission of offer is extended from 20-07-2012 to **31-07-2012 (15-00 hrs)**.
- 3.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder to submit 'No deviation certificate' as per attached format only.
- 4.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

ENGR (SCT)

Encl  
As above.

पावर सेक्टर पूर्वी क्षेत्र ( मुख्यालय )

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

JOB	Design, engineering, manufacturing, supply/ delivery, storage & handling, erection, commissioning, trial run, handing over to customer, etc of Mill Reject Handling System for 1x250 MW unit at DPL, Durgapur, WB..
TENDER NO	PSER:SCT:DPL-M1371:12.

Sl. No	Section/Clause /Page No.	Statement of the referred clause	Clarification required	Reply to the clarification
1.	Volume – IIB, Technical Specification Document No: PE-TS-360-160-A001, Volume: IIA/1, Section – III page No: 11 of 197.	1.00.00 General Description of works	In Technical Specification Document No: PE-TS-360-160-A001, Page No: 11 of 197 indicated 2X250 MW Extension Units – 8 & 9 of the existing Thermal Power Station at Durgapur but in the Notice Inviting Tender indicated 1X250 MW unit at DPL, Durgapur, West Bengal. Please Confirm.	Only single unit, 1x 250 MW is there. Bidder to quote for single unit only.
2.			Please provide the latest Auto Cad Plot Plan Drawing for more clarity.	Drawings enclosed with the specification are very clear. AutoCAD drawings are not required. Specific queries regarding layout may pl. be raised, if any.
3.	Volume – IIB, Technical Specification, Annexure – II, equipment Design/ Selection Criteria Page No – 1 of 4.	01 – Chain Conveyor (a)	As per Technical Specification Document No: PE-TS-360-160-A001, indicated maximum reject generation per mill 0.5 T/Hr. Total No. of mills – 6 {5W + 1S}, Total Mill reject generation is 2.5 TPH for 5 Working Mills, but in Page No: 6 of 9 as indicated Rated Capacity of the Conveyor- 4T/Hr in the same Design capacity of the conveyor – 6 T/Hr. Please clarify the Conveyor capacity	Rated capacity is the expected reject generation i.e. 4TPH. System shall be designed for conveying 6TPH reject. Accordingly, bidder to size the system.
4.	Volume – IIB, Technical Specification, Annexure – II, equipment Design/ Selection Criteria Page No – 1 of 4.	01 – Chain Conveyor (b)	As per Technical Specification Document No: PE-TS-360-160-A001, as indicated Max. Inclination of conveyor – 35 degree if the same is directly feeding the bunker, But as per Layout For Mill Reject Handling System Dwg No: PE-DG-360-160-A002, exceed the specified according to the Horizontal length showing in the Layout drawing. Please let us know the feasibility of re-orientation of Mill reject Bunker.	There is no possibility of shifting the bunker along the mill bay away from the mills as it will foul with the pipe rack. Bidder to accommodate their system in this layout only.

4.	Volume – 1A, General Conditions of contract, Clause No: 8.0 Terms of Payment, Page No: 10 of 22	8.1 - Supply	<p>We request you to accept the following terms of payment since it will be difficult to start the works without advance as per standard practice.</p> <p>10% Advance against bank guarantee.</p> <p>80% against supply of material after site receipt.</p> <p>10% after successful commissioning</p>	Corresponding clause of SCC (Volume-IC) shall prevail
6.	Volume – 1A, General Conditions of contract, Clause No: 8.0 Terms of Payment, Page No: 10 of 22	8.2 – Supervision, Erection and Commissioning/ Supervision of Erection & Commissioning	<p>We request you to accept the following terms of payment since it will be difficult to start the works without advance as per standard practice.</p> <p>10% Advance against bank guarantee.</p> <p>80% against supply of material after site receipt.</p> <p>10% after successful commissioning.</p>	Corresponding clause of SCC (Volume-IC) shall prevail
7.0	All other terms & conditions shall remain unchanged.			

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, SECTOR-II, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691/ 23211798/ 23211796

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply/ delivery, storage & handling, erection, commissioning, trial run, handing over to customer, etc of Mill Reject Handling System for 1x250 MW unit at DPL, Durgapur, WB.	
Ref	1.0	Tender no PSER:SCT:DPL-M1371:12.
	2.0	BHEL's NIT, vide reference no PSER:SCT:DPL-M1371:2862, dated 29-06-2012.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:DPL-M1371:TCN-01, dated 18-07-2012.
	4.0	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691/ 1798