



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT:SNG-M1545:TCN-01

Date: 09/05/2014

Sub	Tender change notice (TCN) 01	
Job	Design, engineering, manufacturing, supply/Delivery, erection, Commissioning, trial run, handing over to customer etc of ventilation System for 2x600MW Unit at Singareni STPP, Adilabad , Andhra pradesh .	
Ref	1.0	Tender no PSER:SCT:SNG-M1545:14
	2.0	BHEL's NIT, vide ref no PSER:SCT:SNG-M1545:3715 Dated 30/04/2014
	3.0	Other references (if any).

With reference to above, following points , relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarifications to bidders queries as per annexure-A to TCN-01.
- 2.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached Format only .
- 3.0 All other terms & conditions shall remain unchanged .

Thanking you,

Yours faithfully,
For BHARAT HEAVY ELECTRICALS LTD

Sr. ENGR (SCT)

Encl

- 1.0 Annexure- A to TCN-01 .
- 2.0 Revised 'No deviation certificate' format.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211495/ 1691

Design, engineering, manufacturing, supply/Delivery, erection, Commissioning, trial run, handing over to customer etc of ventilation System for 2x600MW Unit at Singareni STPP, Adilabad , Andhra pradesh .

Tender no PSER:SCT:SNG-M1545:14

ANNEXURE-A TO TCN-01

Sl. No.	Reference clause of tender document	Existing provision	Bidder's query	BHEL's clarification
1	Clause No. 4, IIIb of NIT	Duly filled-in Volume-IIIB (BOQ-cum-price schedule in percentage value) together with signed preamble in separate sealed envelope.	In Table 3.8, it is mentioned Price Schedule (percentage value is not applicable) and the format is also not given	Volume-IIIB (BOQ - cum - price schedule in percentage value) not applicable for this package .
2	Clause 12 of NIT	Bidders shall submit Integrity Pact Agreement	In Table 11, Integrity pact is not applicable	Integrity pact is not applicable for this package .
3	Sl. no. 1.1.1, SCH-3 SUPPLY PRICE BREAK-UP , VOLUME-IIIA PRICE SCHEDULE, REV-00 ,	(fan capacity 2,50,000 CMH at 75 mmwcstatic pressure)	Single Fan size of 250000 CMH shall be very big. There may be problem for transportation, installation of the same and also balancing of impeller may be difficult. Green Power suggest to supply multiple unit of smaller capacity fans whose total capacity shall be 250000 CMH.	As per tender
4	SCH-6- GUARANTEED POWER CONSUMPTION , VOLUME-IIIA PRICE SCHEDULE, REV-00	RE units and Fan list as per price schedule (Sr. No, 1.1.7.2 to 1.1.12.1) is missing	Please mention various RE units, Axial air supply fans, Axial exhaust fans, etc.	As per tender
5	General - Request for extension of bid submission date.		For preparation of bid, some pre tender engineering to be done and we have to take prices of various bought out items from our vendor. The time provided for submission of tender is very less. We request you to extend the submission date by 1 week more.	No Extension of due date of submission is envisaged in this tender

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply/Delivery, erection, Commissioning, trial run, handing over to customer etc of ventilation System for 2x600MW Unit at Singareni STPP, Adilabad , Andhra pradesh .	
Ref	1.0	Tender no PSER:SCT:SNG-M1545:14
	2.0	BHEL's NIT, vide ref no PSER:SCT:SNG-M1545:3715 Dated 30/04/2014
	3.0	BHEL's TCN-01 , vide ref no PSER:SCT:SNG-M1545:TCN-01 Dated 09/05/2014.
	4.0	Other references (if any) .

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void .

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, Integrity Pact (If applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature , date & seal of authorized
Representative of the bidder)