



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT:SRG-M1574:TCN-01

Date: 23-07-2014

Sub	Tender change notice (TCN) 01	
Job	Design, engineering, manufacturing, supply, erection & commissioning of double girder EOT Crane upto 50T capacity for RRVUNL, 2x660 MW, Stage-V, Unit # 7 & 8 Suratgarh Super Critical TPS, Rajasthan.	
Ref	1.0	Tender No. PSER:SCT:SRG-M1574:14
	2.0	BHEL's NIT, vide reference no PSER:SCT:SRG-M1574:3828, dated 11/07/2014.
	3.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

1.0 The clarifications to bidder query is as follows:

Sl No	Reference Clause of Tender Document	Existing Provision	Bidders Query	BHEL's clarification
01	TECHNICAL SPECIFICATION NO. PE-TS-391-501-A002, CLAUSE NO.3.14.0 (a)	RAILS SECTIONS AS PER IS:3443 GRADE 50C12 OR 50C11. RAIL TO RAIL JOINING SHALL BE BY END CLAMPING ARRANGEMENT.	PROVIDE US LT/CT RAIL TYPE/SECTION	BOTH CT AS WELL AS LT RAIL TYPE/SECTION SHALL BE AS PER IS 3443, SELECTED TO MEET THE WHEEL LOADING REQUIREMENT FOR THE SPECIFIED DUTY CLASS OF THE CRANES. IT IS ALSO FURTHER CLARIFIED THAT THE GRADE INDICATED AT CLAUSE NO 3.14.0 (A) OF TECHNICAL DATA SHEET A, PAGE NO 75 OF 161 OF TECHNICAL SPECIFICATION NO PE-TS-392-501-A002 REV 01 IS TO BE READ AS 55C11 INSTEAD OF 50C11.

2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.

3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HYEAVY ELECTRICALS LTD

ENGR (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply, erection & commissioning of double girder EOT Crane upto 50T capacity for RRVUNL, 2x660 MW, Stage-V, Unit # 7 & 8 Suratgarh Super Critical TPS, Rajasthan.	
Ref	01	Tender No. PSER:SCT:SRG-M1574:14
	02	BHEL's NIT, vide reference no PSER:SCT:SRG-M1574:3828, dated 11/07/2014.
	03	BHEL's TCN-01, vide reference PSER:SCT:SRG-M1574:TCN-01, dated 23-07-2014.
	04	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALLAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796