



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT:SRG-M1596:TCN-01

Date: 06/10/2014

Sub	Tender change notice (TCN) 01	
Job	Design, engineering, supply, erection & commissioning of Coal Mill Reject System Package for, 2x660 MW Super Critical TPS, Stage-V, RRVUNL, Suratgarh, Rajasthan.	
Ref	1.0	Tender no PSER:SCT:SRG-M1596:14
	2.0	BHEL's NIT, vide ref no PSER:SCT:SRG-M1596:3942 Dated 15/09/2014.
	3.0	Other references (if any).

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Due date of submission is extended from 06/10/2014 to **10/10/2014** at 1500 Hrs.
- 2.0 BHEL clarification to TECH. SPEC. has been attached herewith.
- 3.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached Format only.
- 4.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
For BHARAT HEAVY ELECTRICALS LTD

Sr. ENGR (SCT)

Encl

- 1.0 Clarification to TECH. SPEC.
- 2.0 Revised 'No deviation certificate' format.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211495/ 1691

PRE-BID CLARIFICATION ON TECHNICAL SPECIFICATION NO. PE-TS-392-160-A001 FOR MILL REJECT HANDLING SYSTEM FOR 2X660 MW SURATGARH SCTPS

It has been noticed that in flow scheme for MRS attached along with above said specification, number of MRS bunkers have been inadvertently indicated as 1 no. and the capacity has been mentioned as 'Option I / II = 35T / 105T'

It is hereby clarified that total 2 nos. MRS bunkers per unit (i.e. one number bunker per bay) are required for this package and the capacity of each bunker shall be considered as 70T.

Prospective bidders are required to take note of the above and comply accordingly.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, supply, erection & commissioning of Coal Mill Reject System Package for, 2x660 MW Super Critical TPS, Stage-V, RRVUNL, Suratgarh, Rajasthan.	
Ref	1.0	Tender no PSER:SCT:SRG-M1596:14
	2.0	BHEL's NIT, vide ref no PSER:SCT:SRG-M1596:3942 Dated 15/09/2014.
	3.0	BHEL's TCN-01 , vide ref no PSER:SCT:SRG-M1596:TCN-01 Dated 06/10/2014.
	4.0	Other references (if any) .

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, Integrity Pact (If applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
Representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)
POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091
फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691