



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER: SCT: BNP-M1745: TCN-01

Date: 30-05-2016

Sub	Tender Change Notice (TCN) - 01.	
Job	Design, engineering, manufacturing, supply, erection, testing, commissioning, etc of high velocity water spray system for 2x660 MW UNITS AT IB TPS, Banharpalli, Odisha.	
Ref	1.0	Tender no PSER:SCT: BNP-M1745:16
	2.0	BHEL's NIT, vide reference no PSER:SCT:BNP- M1745:16:5013 Date:13/05/16
	3.0	Other References, if any.

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting the offer.

1. Clarification to bidder's queries is attached as per Annexure-A to TCN 01.
2. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
3. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY MGR (SCT)

Encl:

1.0 Annexure-A to TCN-01

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

JOB		DESIGN, ENGINEERING, MANUFACTURING, SUPPLY, ERECTION, TESTING, COMMISSIONING, ETC OF HIGH VELOCITY WATER SPRAY SYSTEM FOR 2x660 MW UNITS AT IB TPS, BANHARPALLI, ODISHA		
TENDER NO		PSER:SCT:BNP-M1745:16		
SL NO	REF CL OF TENDER	EXISTING PROVISION	BIDDER'S QUERY	BHEL'S CLARIFICATION
1	4.2.0 (B)	EXCLUSION: Deluge valves with bypass valve, isolating valve for HVWS system for above areas.	As per clause 4.2.0 (B) and P&I diagram, no FE-DG-391-522-A001, following points are required to confirm. 1. Supply of deluge valves are in BHEL/ OPGCL scope, wheather installation of those are in successful bidder's scope. 2. Supply of bypass valves are in BHEL/ OPGCL scope, wheather installation of those are in successful bidder's scope. 3. Supply of isolating valves are in BHEL/ OPGCL scope, wheather installation of those are in successful bidder's scope. 4. Supply of Y-strainers are in BHEL/ OPGCL scope, wheather installation of those are in successful bidder's scope. 5. Successful bidder's scope starts from down stream of deluge valve as marked in P&I diagram.	As per clause no 4.2.0(B), supply & installation of deluge valves, deluge vale bypass valves, deluge valve side upstream & downstream isolation valves, Y-type strainers is in BHEL/ OPGCL scope. Further, refer 'P&ID of HV water spray system', page no 28 of 89, wherein terminal points are clearly defined between BHEL/ OPGCL and bidder.
2	5.3.8	SPRAY WATER SYSTEM: Deluge valve is excluded from bidder's scope. However, bypass valve for deluge valve to be provided by bidder as a loose supply.	Please clarify the bypass valve for deluge valve to be provided by bidder as a loos supply.	Deluge valve by pass vales are excluded from bidder's scope as per clause no 4.2.0 (B). Further, as there is discrepancy in two clause and clause no 5.3.8 stands deleted.
			Requesting to provide the Pressure and Flow available at all the Tapping Points with the existing Fire Water Pumps details.	Refer 'P&ID of HV water spray system', page no 28 of 89, wherein the flow & pressure at each terminal point is defined. However, in case of high presure available during detail engineering stage, bidder to provide orifice plate to get the desired pressure without any cost implication to BHEL.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply, erection, testing, commissioning, etc of high velocity water spray system for 2x660 MW UNITS AT IB TPS, Banharpalli, Odisha.	
Ref	01	Tender No. PSER:SCT:BNP-M1745:16
	02	BHEL's NIT, vide reference no PSER:SCT:BNP- M1745:16:5013 Date:13/05/16
	03	BHEL's TCN-01,vide reference no PSER:SCT:BNP- M1745:TCN-01 Date: 30/05/16
	04	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)