

BHEL/ PSER-KOLKATA

**TENDER CHANGE NOTICE
(TCN-01 DATED 29/04/2011)**

TENDER NO.:- PSER:PUR:PMX:149(X):006 Dtd.15/04/2011

FOR

SUPPLY OF 04 (FOUR) NOS. LT-KIOSK 415V 800 AMPS AT BHEL:HALDIA SITE

FOLLOWING CLAUSES OF THE AFORESAID TENDER IS TO BE READ AS STATED BELOW:-

(1) Clarification related to Technical Specification :

- a) Ref. cl. 3.5 Switch Board Bus Bars (Part-C, Technical Specification):- “\The neutral bus bar shall be rated at 100% of the phase bus bars.\” (ref. page-12)- is not applicable and shall be ignored.
- b) “\Sub: TENDER DOCUMENT FOR SUPPLY OF 04 (FOUR) NOS. LT-KIOSK 415V 800 AMPS WITH ONE INCOMING & SIX OUTGOING FEEDERS AT BHEL:HALDIA SITE\” (ref. page-1) shall be read as “\Sub: TENDER DOCUMENT FOR SUPPLY OF 04 (FOUR) NOS. LT-KIOSK 415V 800 AMPS AS PER TECHNICAL SPECIFICATION AT BHEL:HALDIA SITE.\”

(2) Due date of submission is extended upto 05/05/2011 (up to 3.00 PM) & Techno-commercial bid shall be opened on 06/05/2011 (at 11:00 AM)

ALL OTHER TERMS & CONDITIONS OF THE ABOVE TENDER SHALL REMAIN UNCHANGED.

BIDDERS ARE REQUESTED TO ACKNOWLEDGE THIS TCN-01 IN THEIR TECHNO-COMMERCIAL OFFER.

**Sr. ENGINEER/ PUR
BHEL:PSER:KOLKATA**