



Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II ,

SALT LAKE CITY , KOLKATA ,WEST BENGAL, INDIA

Phone : 033-23216130-31,033-23216130 FAX : 033-23211960

Sub	TENDER CHANGE NOTICE (TCN-01 DTD. 27/05/14)
Job	"OVERHAULING OF TURBINE, GENERATOR, BEARING INSPECTION & STRAINER WORKS FOR UNIT-2, 525 MW (KWU DESIGN), MAITHON RBTPP, MPL, JHARKHAND."
Ref	TENDER NO.: PSER: PUR: MPL-S147:14: (ENQ:14:PP:0015:PUR:19) DTD.14/05/2014

1) With reference to above, following clarifications, relevant to tender, may please be noted and complied with while submitting the offer.

Sl. No.	Description/ Clause as per NIT	Bidder's Queries	BHEL's Clarifications
1	Annexure - 1 (Scope of work): AA. LPT Module Sub Clause No. 04 BB. General activities of Turbine Sub Clause No. 14	The job (AA-04) has been mentioned again under the point 'BB-14'. If the job (AA-04) is not executed please clarify the deductions.	Sl. No. BB-14 shall now shall be read as follows:- "Centering check, rolling check, axial bump check, swing check & Horn drop test of HP & IP cylinder and correction as required. Fixing and lubrication of all sliding keys & packers of the cylinders etc. maintaining proper clearances. Removal / Dismantling & re-insulation (Pad type) of damaged portion as required".
2	Annexure - 1 (Scope of work): AA. LPT Module: Sub Clause No. 08	Any deductions will be made in case of expansions bellow is not replaced. What will be the percentage to be given if an additional work being done for replacing the expansion bellow of gland box ?	Sl.NO. AA - 08 is now modified as follows:- "Dye Penetration Test of the expansion bellows of the gland box are to be done."
3	Annexure - 1 (Scope of work): BB. General activities of Turbine: Sub Clause No. 06 & 10	Please clarify the deductions if the jobs under BB. 06 & 10 are partially executed.	Percentage (%) deduction, if any, shall be effected proportionately depending on no. of couplings which are decoupled and recoupled.
4	Annexure - 1 (Scope of work): BB. General activities of Turbine: Sub Clause No. 19	If hanger expert has to be arranged even if the checking / setting of hangers are not executed.	Hanger expert shall be deployed for the duration as mentioned in the scope for execution of the hanger checking/setting work as mentioned in the scope failing which percentage (%) deduction shall be effected as per the terms of the tender.
5	Annexure - 1 (Scope of work): CC. MS & HRH strainer removal, inspection, correction and re-installation: Sub Clause No. 05	Since we are not manufacturers / suppliers of insulation materials, it is requested to make arrangement for the same - as always.	Vendor has to execute the reapplication of the insulation for the portions that were de-insulated by them.
6	Annexure - 1 (Scope of work): DD. Generator and Auxiliaries:	Please mention if the barrier is 'SOFT' OR 'HARD'. In case of hard barrier who will supply the materials for the same.	Structure for barrier will be provided by customer. Non inflammable tarpaulin to be provided by the bidder.
7	Annexure - 1 (Scope of work): DD. Generator and Auxiliaries: Sub Clause No. 2.13, 3.7	If any defective part/s are to be replaced (eg. CC bolt, sealing washers) then who will supply the materials?	The consumables etc. other than specifically mentioned in the scope of work under Head 2.13 & 3.7 shall be arranged by customer.

2) 'No deviation certificate' is attached. Bidder to submit their offer along with stamped & signed copy of this TCN & 'No deviation certificate' as per attached format only.

3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD.

DY. MANAGER (PURCHASE)

(Signature, date & seal of authorized representative of the contractor)

[ANNEXURE - IV](#)

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

To,
Bharat Heavy Electricals Limited,
POWER SECTOR – EASTERN REGION
2nd FLOOR, Block-DJ, Plot- 9/1, SECTOR
SALT LAKE CITY, KOLKATA – 700 091
FAX – 033-2321-1960

Sub: NO DEVIATION CERTIFICATE FOR “OVERHAULING OF TURBINE , GENERATOR, BEARING INSPECTION & STRAINER WORKS FOR UNIT-2, 525 MW (KWU DESIGN), MAITHON RBTPP, MPL, JHARKHAND.”

Tender No. PSER: PUR: MPL-S147:14: (ENQ:14:PP:0015:PUR:19) DTD. 14/05/2014 ALONG WITH TCN-01 DTD.27/05/14

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/modified the tender documents as appeared in the website/newspapers and in case of observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT *and confirm our acceptance to reverse auctioning process* and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the contractor)