



Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II ,
SALT LAKE CITY , KOLKATA ,WEST BENGAL, INDIA

Phone : 033-23216130-31,033-23216130 FAX : 033-23211960

Sub	TENDER CHANGE NOTICE (TCN-01 DTD. 18/12/2015)
Job	"OVERHAULING OF TURBINE, GENERATOR & AUXILIARY WORKS AT UNIT-1, 210 MW (KWU DESIGN) AT IB TPS, OPGCL, ODISHA".
Ref	a) TENDER NO.: PSER: PUR: IBV-S201:15 (ENQ:15:PP:0015:PUR:117) Date 03/12/2015. b) Pre Bid Discussion (PBD) dtd. 11/12/2015.

1) [With reference to above, following clarifications, relevant to tender, may please be noted and complied with while submitting the offer.](#)

Sl. no.	Description/ Tender clause	As appeared in tender	Bidder's query	BHEL's reply
1	Clause No. 16.0 of Section-I (HPT MODULE OVERHAULING) of Annexure-I (Scope of Work)	Facial and free run-out measurement. Correction of face as required for getting desired swing values. Transportation of surface plate from CESC/Budge Budge Site (WB) or NTPC/Farakka Site (WB) to IBTPS/OPGCLSite (ODISHA) for face correction and return back to CESC/Budge Budge Site (WB) or NTPC/Farakka Site (WB).	Who will generate the way bill for the to & fro transportation of surface plate from CESC/Budge Budge Site (WB) or NTPC/Farakka Site (WB) to IBTPS/OPGCLSite (Odisha)?	Way bill for the to & fro transportation of surface plate from CESC/Budge Budge Site (WB) or NTPC/Farakka Site (WB) to IBTPS/OPGCLSite (Odisha) will be arranged by BHEL.
2	Clause No. 21.0 of Section-I (HPT MODULE OVERHAULING) of Annexure-I (Scope of Work)	Measurement of 'U' seal ring compression. Replacement of 'U' seal rings as may be required including transportation to & fro BHEL/HARIDWAR.	Who will bear the cost of to & fro transportation from BHEL/Haridwar for 'U' Seal Ring? Will generate the way bill for the same?	Transportation is to be arranged by bidder and cost of to & fro transportation from BHEL/Haridwar for 'U' Seal Ring is to be borne by bidder. Way bill for to & fro transportation from BHEL/Haridwar for 'U' Seal Ring will be arranged by customer IBTPS/BHEL.

Sub	TENDER CHANGE NOTICE (TCN-01 DTD. 18/12/2015)
Job	"OVERHAULING OF TURBINE, GENERATOR & AUXILIARY WORKS AT UNIT-1, 210 MW (KWU DESIGN) AT IB TPS, OPGCL, ODISHA".
Ref	a) TENDER NO.: PSER: PUR: IBV-S201:15 (ENQ:15:PP:0015:PUR:117) Date 03/12/2015. b) Pre Bid Discussion (PBD) dtd. 11/12/2015.

Sl. no.	Description/ Tender clause	As appeared in tender	Bidder's query	BHEL's reply
3	Clause No. 29.0 of Section-I (HPT MODULE OVERHAULING) of Annexure-I (Scope of Work)	Final connections of all pipe lines, breech nuts (02 nos.), welding of pipe lines and stress relieving, UT, X-ray of joints, gland pipes. Arrangement of welding rods, filler rod is included in vendor's scope. CRH gland leak off line replacement by P22 material as may be required. P22 Material will be arranged by customer.	For the CRH gland leak off line replacement, bends if required then whether it shall be supplied readymade or shall be fabricated at site?	<u>Clause is amended as under:-</u> Final connections of all pipe lines, breech nuts (02 nos.), welding of pipe lines and stress relieving, UT, X-ray of joints, gland pipes. Arrangement of welding rods, filler rod is included in vendor's scope. Balance gland leak off line to CRH gland leak off line replacement by P22 material as may be required. P22 Material and bend will be arranged by customer.
4	Clause No. 9.0 of Section-VI (SLOW SPEED BALANCING OF HP & IP ROTOR) of Annexure-I (Scope of Work)	Arrangement of 32 ft trailer, transportation of slow speed balancing machine from KOLAGHAT TPS/WBPDCL Site (WB) to IBTPS/OPGCL Site (ODISHA) and back to KOLAGHAT TPS/WBPDCL Site (WB).	Who will generate the way bill for the to & fro transportation of slow speed balancing machine?	Way bill for the to & fro transportation of Slow Speed Balancing Machine from KOLAGHAT TPS/WBPDCL Site (WB) to IBTPS/OPGCL Site (ODISHA) and back to KOLAGHAT TPS/WBPDCL Site (WB) will be arranged by BHEL.
5	Clause No. 3.0 of Section-V (TURBINE VALVES & HP BYPASS SYSTEM OVERHAULING) of Annexure-I (Scope of Work)	Gland leak off line from HPCVs, SVs, IPCVs and SVs to condenser flash tank against present connection to gland steam header. High pressure welder to be arranged for this modification.	-----	<u>Clause is amended as under:-</u> Gland leak off line from HPCVs, SVs, IPCVs and SVs to condenser flash tank against present connection to gland steam header. High pressure welder and pipe bending machine to be arranged by vendor for this modification.

- 2) 'No deviation certificate' is attached. Bidder to submit their offer along with stamped & signed copy of this TCN & 'No deviation certificate' as per attached format only.
- 3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD.
SR. MANAGER (PURCHASE)

(Signature, date & seal of authorized representative of the contractor)

[ANNEXURE - IV](#)

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

To,
Bharat Heavy Electricals Limited,
POWER SECTOR – EASTERN REGION
2nd FLOOR, Block-DJ, Plot- 9/1, SECTOR
SALT LAKE CITY, KOLKATA – 700 091
FAX – 033-2321-1960

Sub: NO DEVIATION CERTIFICATE FOR TENDER FOR “OVERHAULING OF TURBINE, GENERATOR & AUXILIARY WORKS AT UNIT-1, 210 MW (KWU DESIGN) AT IB TPS, OPGCL, ODISHA”.

E-Tender No.: PSER: PUR: IBV-S201:15 (ENQ:15:PP:0015:PUR:117) Date 03/12/2015 along with TCN-01 DTD. 18/12/2015)

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/modified the tender documents as appeared in the website/newspapers and in case of observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT *and confirm our acceptance to **reverse auctioning process*** and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the contractor)