



Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II ,

SALT LAKE CITY , KOLKATA ,WEST BENGAL, INDIA

Phone : 033-23216130-31,033-23216130 FAX : 033-23211960

TENDER CHANGE NOTICE

Sub	TENDER CHANGE NOTICE (TCN-01 DTD. 13/02/2015)
Job	“OVERHAULING OF TURBINE (ALL MODULES), GENERATOR & AUXILIARY WORKS FOR UNIT-5, 250 MW (KWU DESIGN), MEJIA TPS, DVC, WEST BENGAL”.
Ref	TENDER NO.: PSER: PUR: MJA-S168:14:(ENQ:14:PP:0015:PUR:157) Date: 03/02/2015.

1) [With reference to above, following clarifications / changes, relevant to tender, may please be noted and complied with while submitting the offer.](#)

Sl. no.	Description/ Tender clause	Bidder's queries	BHEL's Clarification
1	Scope of work of Annexure-I, AA: HPT Module Overhauling, sub clause 3.0	Whether bidder has to provide induction heating machine for opening and closing of CRH pipe flange bolts?	Induction heating equipment along with operator will be provided by BHEL as already mentioned in Note of Scope AA.
2	Scope of work of Annexure-I, BB: IPT Module Overhauling, sub clause 8.0 & 9.0	Whether bidder has to provide induction heating machine for opening and closing of IP out casing and inner casing P/P bolts?	Induction heating equipment along with operator will be provided by BHEL.
3	Scope of work of Annexure-I, CC: LPT Module Overhauling, sub clause 1.0	Whether bidder has to provide induction heating machine for opening and closing of LP casing P/P bolts?	Induction heating equipment along with operator will be provided by BHEL.
4	Scope of work of Annexure-I, CC: LPT Module Overhauling, sub clause 15.0	Whether any deductions will be made in case of expansion and extraction bellows are not replaced? If not be replaced what will be the percentage of deduction?	<p>As per technical scope it is to note that “in case In case any part of the job is not required to be carried out, a deduction will be effected as per percentage shown against those items”.</p> <p>Also as per SCC clause no. 03(iii) , Payment terms : “BHEL at its discretion may further split up the percentage break-up given in billing schedule and effect payment to suit site condition, cash flow requirement etc. according to progress of work”.</p> <p>Based on above BHEL-EIC shall decide for further percentage break-up if necessary as per requirement which shall be final & binding on bidder.</p>

Sl. no.	Description/ Tender clause	Bidder's queries	BHEL's Clarification
5	Scope of work of Annexure-I, EE: Turbine Valves & LP Bypass System Overhauling, sub clause (j)	Whether bidder has to supply insulation materials related to this scope?	Supply insulation materials related to that scope is in bidder's scope.
6	Scope of work of Annexure-I, EE: Turbine Valves & LP Bypass System Overhauling	Whether bidder has to provide special type of electrodes rods for valve seat welding?	Supply of special type of electrodes rods for valve seat welding (if any required) is in Customer DVC's scope i.e. not in bidder's scope.

- 2) 'No deviation certificate' is attached. Bidder to submit their offer along with stamped & signed copy of this TCN & 'No deviation certificate' as per attached format only.
- 3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY. MANAGER (PURCHASE)

(Signature, date & seal of authorized representative of the contractor)

ANNEXURE - IV

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

To,
Bharat Heavy Electricals Limited,
POWER SECTOR – EASTERN REGION
2nd FLOOR, Block-DJ, Plot- 9/1, SECTOR
SALT LAKE CITY, KOLKATA – 700 091
FAX – 033-2321-1960

Sub: NO DEVIATION CERTIFICATE FOR “OVERHAULING OF TURBINE (ALL MODULES), GENERATOR & AUXILIARY WORKS FOR UNIT-5, 250 MW (KWU DESIGN), MEJIA TPS, DVC, WEST BENGAL”.

Tender No. PSER: PUR: MJA-S168:14:(ENQ:14:PP:0015:PUR:157) Date: 03/02/2015 ALONG WITH TENDER CHANGE NOTICE (TCN-01 DTD. 13/02/2015).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/modified the tender documents as appeared in the website/newspapers and in case of observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT *and confirm our acceptance to **reverse auctioning process*** and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the contractor)