



Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II , SALT LAKE CITY , KOLKATA
, WEST BENGAL, INDIA

Phone : 033-23216130-31,033-23216130 FAX : 033-23211960

Sub	TENDER CHANGE NOTICE (TCN-01) DATED: 19/07/2013.
Job	“OVERHAULING OF GENERATOR, BEARING INSPECTION WITH ASSOCIATED VALVES & EXCITER, PMG ETC. AT UNIT-1, 525 MW, MAITHON TPS, MPL, JHARKHAND”.
Ref	TENDER NO.: PSER: PUR: MPL-S115:13: ENQ: 13: PP: 0015: PUR 71 DATE: 16/07/2013

Bidders please note following technical clarifications:--

Sl. no.	Description/ tender clause	Bidder's Queries	BHEL's Clarifications
1	Annexure - I (Scope of work): Part -BB.(General Actives of Turbine): Sub Clause No. 18	Hangers in between Valve to Turbine Casing or up to boiler?	Hngers up to Boiler
2	Annexure - I (Scope of work) Part -CC.(MS & HRH Strainer removal, Inspection, Correction & Re-installation): Sub Clause No. 3	Who will provide insulation Material?	Insulating material is in customer's scope.
3	Annexure - I (Scope of work) Generator and Auxiliaries : Sub Clause No. 1.1	Whether Customer will provide 1000V DC source & Micro ampere meter?	Customer will not provide the same, hence both are in vendor's scope.
4	Annexure - I (Scope of work) Generator and Auxiliaries : Sub Clause No. 1.20	Whether customer will provide varnish?	Customer will provide varnish.
5	Annexure - I (Scope of work) Generator and Auxiliaries : Sub Clause No. 2.13 & Sub clause no. 3.7	Whether EX - BHEL Technician will be Required if no leakages found during testing and any deduction in such case will be applicable?	Ex-BHEL technician not required if there will be no leakage. In that case the allocated % will not be applicable.
6	Annexure - I (Scope of work): Generator and Auxiliaries: Sub Clause No. 10.1- (e, f & g.)	Whether deleted from vendor scope?	Not deleted from vendor scope, it is in vendor's scope.

BIDDERS ARE REQUESTED TO ACKNOWLEDGE THIS TCN-01 AS A TOKEN OF ACCEPTANCE IN THEIR TECHNO-COMMERCIAL OFFER.

ALL OTHER TERMS AND CONDITIONS OF THE SUBJECT TENDER SHALL REMAIN UNCHANGED.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY. MANAGER (PURCHASE)

ANNEXURE - IV

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

To,
Bharat Heavy Electricals Limited,
POWER SECTOR – EASTERN REGION
2nd FLOOR, Block-DJ, Plot- 9/1, SECTOR
SALT LAKE CITY, KOLKATA – 700 091
FAX – 033-2321-1960

Sub: NO DEVIATION CERTIFICATE “OVERHAULING OF GENERATOR, BEARING INSPECTION WITH ASSOCIATED VALVES & EXCITER, PMG ETC. AT UNIT-1, 525 MW, MAITHON TPS, MPL, JHARKHAND”.

Tender No. PSER: PUR: MPL-S115:13: ENQ:13:PP:0015:PUR:71 DATE: 16/07/2013, ALONG WITH TENDER CHANGE NOTICE (TCN-01) DATED: 19/07/2013

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/modified the tender documents as appeared in the website/newspapers and in case of observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT and confirm our acceptance to **reverse auctioning process** and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the contractor)